National Accreditation Board for Testing and Calibration Laboratories

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 1 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
Permanent Facility				
1	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 5-2)
2	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 5-2)
3	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Degree of protection; Protection against electric shock	IEC 60529
4	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Degree of protection; Protection against electric shock	IEC 60947 (Part 1)
5	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Degree of protection; Protection against electric shock	IS/IEC 60947 (Part 1)
6	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric properties	IEC 60947 (Part 2)
7	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric properties	IEC 60947 (Part 2)
8	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric properties	IS/IEC 60947 (Part 2)
9	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric properties	IS/IEC 60947 (Part 2)
10	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric test (Impulse test)	IEC 60947 (Part 2)
11	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric test (Impulse test)	IEC 60947 (Part 2)
12	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric test (Impulse test)	IEC 60947 (Part 2)
13	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric test (Impulse test)	IS/IEC 60947 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 2 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
14	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric test (Impulse test)	IS/IEC 60947 (Part 2)
15	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric test (Impulse test)	IS/IEC 60947 (Part 2)
16	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 2)
17	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 2)
18	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric test (Power frequency voltage withstand test)	IS/IEC 60947 (Part 2)
19	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Dielectric test (Power frequency voltage withstand test)	IS/IEC 60947 (Part 2)
20	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Glow wire	IEC 60695 (Part 2-10)
21	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Glow wire	IEC 60695 (Part 2-11)
22	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Glow wire	IEC 60947 (Part 1)
23	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Glow wire	IS/IEC 60947 (Part 1)
24	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Leakage current	IEC 60947 (Part 2)
25	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Leakage current	IEC 60947 (Part 2)
26	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Leakage current	IS/IEC 60947 (Part 2)
27	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	circuit breaker	Leakage current	IS/IEC 60947 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	3 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
28	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Operational performance	IEC 60947 (Part 2)
29	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Operational performance	IS/IEC 60947 (Part 2)
30	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Overload performance	IEC 60947 (Part 2)
31	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Overload performance	IS/IEC 60947 (Part 2)
32	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Overload Releases	IEC 60947 (Part 2)
33	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Overload Releases	IEC 60947 (Part 2)
34	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	circuit breaker	Overload Releases	IS/IEC 60947 (Part 2)
35	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Overload Releases	IS/IEC 60947 (Part 2)
36	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Power loss	IEC 60947 (Part 2)
37	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Power loss	IS/IEC 60947 (Part 2)
38	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Strength of actuator mechanism	IEC 60947 (Part 1)
39	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Strength of actuator mechanism	IS/IEC 60947 (Part 1)
40	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Temperature rise	IEC 60947 (Part 2)
41	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Temperature rise	IS/IEC 60947 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	4 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
42	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Temperature rise	IS/IEC 60947 (Part 2)
43	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Tripping limits and Characteristics	IEC 60947 (Part 2)
44	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Tripping limits and Characteristics	IEC 60947 (Part 2)
45	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Tripping limits and Characteristics	IS/IEC 60947 (Part 2)
46	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Tripping limits and Characteristics	IS/IEC 60947 (Part 2)
47	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Under voltage and shunt releases	IEC 60947 (Part 2)
48	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Under voltage and shunt releases	IS/IEC 60947 (Part 2)
49	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Verification of main contact position	IEC 60947 (Part 2)
50	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Verification of main contact position	IS/IEC 60947 (Part 2)
51	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breaker	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60947 (Part 2)
52	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated service short circuit breaking capacity	IS/IEC 60947 (Part 2)
53	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Clearances and creepage Distances	IEC 60947 (Part 2)
54	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Clearances and creepage Distances	IS/IEC 60947 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 5 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
55	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Conditional short Circuit current	IEC 60947 (Part 2)
56	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Conditional short Circuit current	IEC 60947 (Part 2)
57	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Conditional short Circuit current	IEC 60947 (Part 2)
58	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Conditional short Circuit current	IS/IEC 60947 (Part 2)
59	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Conditional short Circuit current	IS/IEC 60947 (Part 2)
60	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Conditional short Circuit current	IS/IEC 60947 (Part 2)
61	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Discrimination between SCPD and overcurrent relay	IEC 60947 (Part 2)
62	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Discrimination between SCPD and overcurrent relay	IEC 60947 (Part 2)
63	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Discrimination between SCPD and overcurrent relay	IEC 60947 (Part 2)
64	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Discrimination between SCPD and overcurrent relay	IS/IEC 60947 (Part 2)
65	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Discrimination between SCPD and overcurrent relay	IS/IEC 60947 (Part 2)
66	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Discrimination between SCPD and overcurrent relay	IS/IEC 60947 (Part 2)
67	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Dry heat	IEC 60068 (Part 2-14)
68	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Dry heat	IEC 60068 (Part 2-30)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	6 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
69	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Dry heat	IEC 60947 (Part 2)
70	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Dry heat	IS/IEC 60947 (Part 2)
71	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Dry heat	IS/IEC 60947 (Part 2)
72	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Dry heat	IEC 60947 (Part 2)
73	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit breakers	Electrical endurance	IEC 60947 (Part 2)
74	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Electrical endurance	IS/IEC 60947 (Part 2)
75	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	General	IEC 60947 (Part 1)
76	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	General	IS/IEC 60947 (Part 1)
77	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Individual pole short circuit breaking capacity	IEC 60947 (Part 2)
78	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Individual pole short circuit breaking capacity	IEC 60947 (Part 2)
79	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Individual pole short circuit breaking capacity	IEC 60947 (Part 2)
80	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Individual pole short circuit breaking capacity	IS/IEC 60947 (Part 2)
81	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Individual pole short circuit breaking capacity	IS/IEC 60947 (Part 2)
82	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Individual pole short circuit breaking capacity	IS/IEC 60947 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	7 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
83	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Mechanical operational performance capability	IEC 60947 (Part 2)
84	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Mechanical operational performance capability	IS/IEC 60947 (Part 2)
85	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Moisture and humidity test	IE 60068 (Part 2-14)
86	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Moisture and humidity test	IE 60068 (Part 2-14)
87	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Moisture and humidity test	IEC 60068 (Part 2-30)
88	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Moisture and humidity test	IEC 60068 (Part 2-30)
89	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Operation and operating limits	IEC 60947 (Part 2)
90	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Operation and operating limits	IEC 60947 (Part 2)
91	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Operation and operating limits	IS/IEC 60947 (Part 2)
92	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Operation and operating limits	IS/IEC 60947 (Part 2)
93	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated service short circuit breaking capacity	IEC 60947 (Part 2)
94	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated service short circuit breaking capacity	IEC 60947 (Part 2)
95	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated service short circuit breaking capacity	IEC 60947 (Part 2)
96	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated service short circuit breaking capacity	IS/IEC 60947 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	8 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
97	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated service short circuit breaking capacity	IS/IEC 60947 (Part 2)
98	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated ultimate short circuit breaking capacity	IEC 60947 (Part 2)
99	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated ultimate short circuit breaking capacity	IEC 60947 (Part 2)
100	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated ultimate short circuit breaking capacity	IEC 60947 (Part 2)
101	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated ultimate short circuit breaking capacity	IS/IEC 60947 (Part 2)
102	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated ultimate short circuit breaking capacity	IS/IEC 60947 (Part 2)
103	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Rated ultimate short circuit breaking capacity	IS/IEC 60947 (Part 2)
104	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at 1.1 times take over current	IEC 60947 (Part 2)
105	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at 1.1 times take over current	IEC 60947 (Part 2)
106	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at 1.1 times take over current	IEC 60947 (Part 2)
107	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at 1.1 times take over current	IS/IEC 60947 (Part 2)
108	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at 1.1 times take over current	IS/IEC 60947 (Part 2)
109	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at 1.1 times take over current	IS/IEC 60947 (Part 2)
110	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at selectivity limit current	IEC 60947 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 9 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
111	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at selectivity limit current	IEC 60947 (Part 2)
112	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at selectivity limit current	IEC 60947 (Part 2)
113	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at selectivity limit current	IS/IEC 60947 (Part 2)
114	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at selectivity limit current	IS/IEC 60947 (Part 2)
115	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit at selectivity limit current	IS/IEC 60947 (Part 2)
116	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit Breaking capacity at Maximum short time withstand current	IEC 60947 (Part 2)
117	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit Breaking capacity at Maximum short time withstand current	IEC 60947 (Part 2)
118	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit Breaking capacity at Maximum short time withstand current	IEC 60947 (Part 2)
119	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit Breaking capacity at Maximum short time withstand current	IS/IEC 60947 (Part 2)
120	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit Breaking capacity at Maximum short time withstand current	IS/IEC 60947 (Part 2)
121	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit Breaking capacity at Maximum short time withstand current	IS/IEC 60947 (Part 2)
122	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit making capacity	IEC 60947 (Part 2)
123	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit making capacity	IEC 60947 (Part 2)
124	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit making capacity	IEC 60947 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 10 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
125	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit making capacity	IS/IEC 60947 (Part 2)
126	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit making capacity	IS/IEC 60947 (Part 2)
127	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short circuit making capacity	IS/IEC 60947 (Part 2)
128	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short time withstand current	IEC 60947 (Part 2)
129	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short time withstand current	IEC 60947 (Part 2)
130	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short time withstand current	IEC 60947 (Part 2)
131	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short time withstand current	IS/IEC 60947 (Part 2)
132	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	circuit breakers	Short time withstand current	IS/IEC 60947 (Part 2)
133	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Short time withstand current	IS/IEC 60947 (Part 2)
134	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Temperature rise	IEC 60947 (Part 2)
135	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS/IEC 60947 (Part 2)
136	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Verification of the coordination at rated conditional residual short circuit current	IEC 60947 (Part 2)
137	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Verification of the coordination at rated conditional residual short circuit current	IEC 60947 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 11 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
138	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Verification of the coordination at rated conditional residual short circuit current	IS/IEC 60947 (Part 2)
139	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Verification of the coordination at rated conditional residual short circuit current	IS/IEC 60947 (Part 2)
140	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Verification of the Rated residual making and breaking capacity	IEC 60947 (Part 2)
141	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Verification of the Rated residual making and breaking capacity	IEC 60947 (Part 2)
142	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Verification of the Rated residual making and breaking capacity	IS/IEC 60947 (Part 2)
143	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Circuit Breakers	Verification of the Rated residual making and breaking capacity	IS/IEC 60947 (Part 2)
144	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses & fuse links	Breaking capacity	IS 13703 (Part 2-2)
145	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IEC 60269 (Part 1)
146	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IEC 60269 (Part 1)
147	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IEC 60269 (Part 1)
148	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IEC 60269 (Part 2)
149	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IEC 60269 (Part 2)
150	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IEC 60269 (Part 2)
151	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IS 13703 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 12 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
152	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IS 13703 (Part 1)
153	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IS 13703 (Part 1)
154	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IS 13703 (Part 2-1)
155	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IS 13703 (Part 2-1)
156	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IS 13703 (Part 2-1)
157	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IS 13703 (Part 2-2)
158	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Breaking capacity	IS 13703 (Part 2-2)
159	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional cable overload protection	IEC 60269 (Part 1)
160	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional cable overload protection	IEC 60269 (Part 1)
161	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional cable overload protection	IEC 60269 (Part 2)
162	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional cable overload protection	IEC 60269 (Part 2)
163	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional cable overload protection	IS 13703 (Part 1)
164	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional cable overload protection	IS 13703 (Part 1)
165	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional cable overload protection	IS 13703 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	13 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
166	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional cable overload protection	IS 13703 (Part 2-1)
167	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional fusing current	IEC 60269 (Part 1)
168	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional fusing current	IEC 60269 (Part 1)
169	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional fusing current	IEC 60269 (Part 2)
170	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional fusing current	IEC 60269 (Part 2)
171	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional fusing current	IS 13703 (Part 2-1)
172	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional fusing current	IS 13703 (Part 2-1)
173	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional fusing current	IS 13703 (Part 2-2)
174	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional fusing current	IS 13703 (Part 2-2)
175	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional non fusing current	IEC 60269 (Part 1)
176	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional non fusing current	IEC 60269 (Part 1)
177	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional non fusing current	IEC 60269 (Part 2)
178	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional non fusing current	IEC 60269 (Part 2)
179	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional non fusing current	IS 13703 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 14 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
180	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional non fusing current	IS 13703 (Part 2-1)
181	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional non fusing current	IS 13703 (Part 2-2)
182	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Conventional non fusing current	IS 13703 (Part 2-2)
183	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Cut-off current characteristics	IEC 60269 (Part 1)
184	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Cut-off current characteristics	IEC 60269 (Part 1)
185	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Cut-off current characteristics	IEC 60269 (Part 2)
186	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Cut-off current characteristics	IEC 60269 (Part 2)
187	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Cut-off current characteristics	IS 13703 (Part 1)
188	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Cut-off current characteristics	IS 13703 (Part 1)
189	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Cut-off current characteristics	IS 13703 (Part 2-1)
190	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Cut-off current characteristics	IS 13703 (Part 2-1)
191	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Cut-off current characteristics	IS 13703 (Part 2-2)
192	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Cut-off current characteristics	IS 13703 (Part 2-2)
193	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Degree of protection, Protection against electric shock	IEC 60269 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	15 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
194	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Degree of protection, Protection against electric shock	IEC 60269 (Part 2)
195	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Degree of protection, Protection against electric shock	IS 13703 (Part 1)
196	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Degree of protection, Protection against electric shock	IS 13703 (Part 2-1)
197	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IEC 60269 (Part 1)
198	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IEC 60269 (Part 1)
199	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IEC 60269 (Part 1)
200	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IEC 60269 (Part 2)
201	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IEC 60269 (Part 2)
202	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IEC 60269 (Part 2)
203	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IS 13703 (Part 1)
204	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IS 13703 (Part 1)
205	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IS 13703 (Part 1)
206	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IS 13703 (Part 2-1)
207	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IS 13703 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 16 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
208	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IS 13703 (Part 2-1)
209	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IS 13703 (Part 2-2)
210	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IS 13703 (Part 2-2)
211	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric test (Impulse test)	IS 13703 (Part 2-2)
212	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric tests (Power frequency voltage withstand tests), Insulating Properties	IEC 60269 (Part 1)
213	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric tests (Power frequency voltage withstand tests), Insulating Properties	IEC 60269 (Part 1)
214	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric tests (Power frequency voltage withstand tests), Insulating Properties	IS 13703 (Part 1)
215	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Dielectric tests (Power frequency voltage withstand tests), Insulating Properties	IS 13703 (Part 2-1)
216	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	I2t characteristics and overcurrent discrimination	IEC 60269 (Part 1)
217	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	I2t characteristics and overcurrent discrimination	IEC 60269 (Part 1)
218	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	I2t characteristics and overcurrent discrimination	IEC 60269 (Part 2)
219	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	I2t characteristics and overcurrent discrimination	IEC 60269 (Part 2)
220	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	I2t characteristics and overcurrent discrimination	IS 13703 (Part 1)
221	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	I2t characteristics and overcurrent discrimination	IS 13703 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 17 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
222	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	I2t characteristics and overcurrent discrimination	IS 13703 (Part 2-1)
223	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	I2t characteristics and overcurrent discrimination	IS 13703 (Part 2-1)
224	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	I2t characteristics and overcurrent discrimination	IS 13703 (Part 2-2)
225	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	I2t characteristics and overcurrent discrimination	IS 13703 (Part 2-2)
226	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Insulation resistance	IEC 60269 (Part 1)
227	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Insulation resistance	IEC 60269 (Part 1)
228	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Insulation resistance	IS 13703 (Part 1)
229	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Insulation resistance	IS 13703 (Part 1)
230	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Mechanical strength	IEC 60269 (Part 1)
231	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Mechanical strength	IEC 60269 (Part 2)
232	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Mechanical strength	IS 13703 (Part 1)
233	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Mechanical strength	IS 13703 (Part 2-1)
234	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Mechanical strength	IS 13703 (Part 2-2)
235	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Non-deterioration of contacts	IEC 60269 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 18 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
236	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Non-deterioration of contacts	IEC 60269 (Part 2)
237	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Non-deterioration of contacts	IS 13703 (Part 1)
238	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Non-deterioration of contacts	IS 13703 (Part 2-1)
239	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation & operating limits	IEC 60269 (Part 1)
240	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation & operating limits	IEC 60269 (Part 1)
241	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation & operating limits	IEC 60269 (Part 2)
242	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation & operating limits	IEC 60269 (Part 2)
243	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation & operating limits	IS 13703 (Part 1)
244	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation & operating limits	IS 13703 (Part 1)
245	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation & operating limits	IS 13703 (Part 2-1)
246	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation & operating limits	IS 13703 (Part 2-1)
247	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation of indicating device and striker	IEC 60269 (Part 1)
248	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation of indicating device and striker	IEC 60269 (Part 1)
249	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation of indicating device and striker	IEC 60269 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 19 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
250	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation of indicating device and striker	IEC 60269 (Part 2)
251	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation of indicating device and striker	IS 13703 (Part 1)
252	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation of indicating device and striker	IS 13703 (Part 1)
253	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation of indicating device and striker	IS 13703 (Part 2-1)
254	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Operation of indicating device and striker	IS 13703 (Part 2-1)
255	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Overload	EC 60269 (Part 1)
256	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance of heat	IEC 60269 (Part 1)
257	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance of heat	IEC 60269 (Part 2)
258	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance of heat	IS 13703 (Part 1)
259	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance of heat	IS 13703 (Part 2-1)
260	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance of heat	IS 13703 (Part 2-2)
261	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to abnormal heat and fire	IEC 60269 (Part 1)
262	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to abnormal heat and fire	IEC 60269 (Part 2)
263	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to abnormal heat and fire	IS 13703 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	20 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
264	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to abnormal heat and fire	IS 13703 (Part 2-1)
265	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to rusting	IEC 60269 (Part 1)
266	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to rusting	IEC 60269 (Part 1)
267	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to rusting	IEC 60269 (Part 2)
268	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to rusting	IEC 60269 (Part 2)
269	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to rusting	IS 13703 (Part 1)
270	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to rusting	IS 13703 (Part 1)
271	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to rusting	IS 13703 (Part 2-1)
272	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Resistance to rusting	IS 13703 (Part 2-1)
273	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IEC 60269 (Part 1)
274	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IEC 60269 (Part 1)
275	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IEC 60269 (Part 1)
276	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IEC 60269 (Part 2)
277	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IEC 60269 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 21 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
278	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IEC 60269 (Part 2)
279	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IS 13703 (Part 1)
280	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IS 13703 (Part 1)
281	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IS 13703 (Part 1)
282	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IS 13703 (Part 2-1)
283	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IS 13703 (Part 2-1)
284	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature cycle test; Verification of non deterioration of contacts	IS 13703 (Part 2-1)
285	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IEC 60269 (Part 1)
286	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IEC 60269 (Part 1)
287	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IEC 60269 (Part 1)
288	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IEC 60269 (Part 2)
289	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IEC 60269 (Part 2)
290	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IEC 60269 (Part 2)
291	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IS 13703 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 22 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
292	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IS 13703 (Part 1)
293	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IS 13703 (Part 1)
294	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IS 13703 (Part 2-1)
295	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IS 13703 (Part 2-1)
296	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Temperature Rise & Power dissipation	IS 13703 (Part 2-1)
297	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Time-current characteristics, gates	IEC 60269 (Part 1)
298	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Time-current characteristics, gates	IEC 60269 (Part 1)
299	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Time-current characteristics, gates	IEC 60269 (Part 2)
300	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Time-current characteristics, gates	IEC 60269 (Part 2)
301	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Time-current characteristics, gates	IS 13703 (Part 1)
302	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Time-current characteristics, gates	IS 13703 (Part 1)
303	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Time-current characteristics, gates	IS 13703 (Part 2-1)
304	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Time-current characteristics, gates	IS 13703 (Part 2-1)
305	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Time-current characteristics, gates	IS 13703 (Part 2-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 23 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
306	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Time-current characteristics, gates	IS 13703 (Part 2-2)
307	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Verification of Constructional requirements, Dimensions, Marking, General requirements	IEC 60269 (Part 1)
308	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Verification of Constructional requirements, Dimensions, Marking, General requirements	IEC 60269 (Part 2)
309	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Verification of Constructional requirements, Dimensions, Marking, General requirements	IS 13703 (Part 1)
310	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Verification of Constructional requirements, Dimensions, Marking, General requirements	IS 13703 (Part 2-1)
311	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Verification of Constructional requirements, Dimensions, Marking, General requirements	IS 13703 (Part 2-2)
312	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Verification of rated current	IEC 60269 (Part 1)
313	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Verification of rated current	IEC 60269 (Part 2)
314	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Verification of rated current	IS 13703 (Part 1)
315	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Verification of rated current	IS 13703 (Part 2-1)
316	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Fuses and Fuse links	Verification of rated current	IS 13703 (Part 2-2)
317	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Clearance and creepage distances	IEC 61439 (Part 1)
318	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Clearance and creepage distances	IEC 61439 (Part 3)
319	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Clearance and creepage distances	IEC 61439 (Part 6)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	24 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
320	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Clearance and creepage distances	IS 8623 (Part 1) 'Withdrawn standard'
321	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Clearance and creepage distances	IS 8623 (Part 2)
322	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Clearance and creepage distances	IS 8623 (Part 3)
323	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Constructional requirements, Dimensions, Marking, General	IEC 61439 (Part 1)
324	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Constructional requirements, Dimensions, Marking, General	IEC 61439 (Part 2)
325	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Constructional requirements, Dimensions, Marking, General	IEC 61439 (Part 3)
326	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Constructional requirements, Dimensions, Marking, General	IEC 61439 (Part 6)
327	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Constructional requirements, Dimensions, Marking, General	IS 8623 (Part 1)
328	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Degree of protection	IEC 61439 (Part 1)
329	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Degree of protection	IEC 61439 (Part 2)
330	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Degree of protection	IEC 61439 (Part 3)
331	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Degree of protection	IEC 61439 (Part 6)
332	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Degree of protection	IS 8623 (Part 1)
333	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Degree of protection	IS 8623 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 25 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
334	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Degree of protection	IS 8623 (Part 3)
335	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Dielectric test (Impulse test)	IEC 60947 (Part 6-1)
336	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Effective connection between the exposed conductive parts of the assembly and the protective circuit by inspection or by resistance measurement	IEC 61439 (Part 3)
337	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Effective connection between the exposed conductive parts of the assembly and the protective circuit by inspection or by resistance measurement	IEC 61439 (Part 6)
338	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Effective connection between the exposed conductive parts of the assembly and the protective circuit by inspection or by resistance measurement	IS 8623 (Part 1) 'Withdrawn standard'
339	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Effective connection between the exposed conductive parts of the assembly and the protective circuit by inspection or by resistance measurement	IS 8623 (Part 2)
340	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Effective connection between the exposed conductive parts of the assembly and the protective circuit by inspection or by resistance measurement	IS 8623 (Part 3)
341	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Mechanical operation	IEC 61439 (Part 1)
342	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Mechanical operation	IEC 61439 (Part 2)
343	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Mechanical operation	IEC 61439 (Part 3)
344	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Mechanical operation	IEC 61439 (Part 6)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	26 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
345	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Mechanical operation	IS 8623 (Part 1) 'Withdrawn standard'
346	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Mechanical operation	IS 8623 (Part 2)
347	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Mechanical operation	IS 8623 (Part 3)
348	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Mechanical strength of fastening means of enclosures	IEC 61439 (Part 3)
349	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Mechanical strength of fastening means of enclosures	IS 8623 (Part 3)
350	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance of insulation materials to abnormal heat and fire	IEC 61439 (Part 1)
351	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance of insulation materials to abnormal heat and fire	IEC 61439 (Part 2)
352	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance of insulation materials to abnormal heat and fire	IEC 61439 (Part 3)
353	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance of insulation materials to abnormal heat and fire	IEC 61439 (Part 6)
354	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance of insulation materials to abnormal heat and fire	IS 8623 (Part 3)
355	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance to rusting and humidity	IEC 61439 (Part 1)
356	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance to rusting and humidity	IEC 61439 (Part 1)
357	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance to rusting and humidity	IEC 61439 (Part 2)
358	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance to rusting and humidity	IEC 61439 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 27 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
359	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance to rusting and humidity	IEC 61439 (Part 3)
360	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance to rusting and humidity	IEC 61439 (Part 6)
361	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance to rusting and humidity	IEC 61439 (Part 6)
362	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance to rusting and humidity	IS 8623 (Part 3)
363	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Resistance to rusting and humidity	IS 8623 (Part 3)
364	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IEC 61439 (Part 1)
365	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IEC 61439 (Part 3)
366	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IEC 61439 (Part 3)
367	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IS 8623 (Part 1)
368	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IS 8623 (Part 1) 'Withdrawn standard'
369	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IS 8623 (Part 2)
370	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IS 8623 (Part 2)
371	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IS 8623 (Part 3)
372	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IS 8623 (Part 3)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 28 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
373	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IEC 61439 (Part 1)
374	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IEC 61439 (Part 6)
375	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of dielectric properties	IEC 61439 (Part 6)
376	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of short-circuit withstand strength of the protective circuit	IEC 61439 (Part 1)
377	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of short-circuit withstand strength of the protective circuit	IEC 61439 (Part 2)
378	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of short-circuit withstand strength of the protective circuit	IEC 61439 (Part 3)
379	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of short-circuit withstand strength of the protective circuit	IEC 61439 (Part 6)
380	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of short-circuit withstand strength of the protective circuit	IS 8623 (Part 1) 'Withdrawn standard'
381	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of short-circuit withstand strength of the protective circuit	IS 8623 (Part 2)
382	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of short-circuit withstand strength of the protective circuit	IS 8623 (Part 3)
383	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IEC 61439 (Part 1)
384	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IEC 61439 (Part 1)
385	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IEC 61439 (Part 1)
386	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IEC 61439 (Part 3)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	29 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
387	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IEC 61439 (Part 3)
388	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IEC 61439 (Part 3)
389	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IEC 61439 (Part 6)
390	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IEC 61439 (Part 6)
391	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IS 8623 (Part 1)
392	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IS 8623 (Part 1)
393	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IS 8623 (Part 1) 'Withdrawn standard'
394	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IS 8623 (Part 2)
395	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IS 8623 (Part 2)
396	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IS 8623 (Part 2)
397	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IS 8623 (Part 3)
398	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IS 8623 (Part 3)
399	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IS 8623 (Part 3)
400	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Low voltage switchgear and control gear assemblies	Verification of temperature rise limits	IEC 61439 (Part 6)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	30 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
401	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Clearances and creepage Distances	IEC 60947 (Part 1)
402	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Clearances and creepage Distances	IEC 60947 (Part 4-1)
403	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Clearances and creepage Distances	IEC 60947 (Part 5-1)
404	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Clearances and creepage Distances	IS/IEC 60947 (Part 1)
405	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Clearances and creepage Distances	IS/IEC 60947 (Part 4-1)
406	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Clearances and creepage Distances	IS/IEC 60947 (Part 5-1)
407	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IEC 60947 (Part 1)
408	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IEC 60947 (Part 1)
409	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IEC 60947 (Part 1)
410	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IEC 60947 (Part 4-1)
411	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IEC 60947 (Part 4-1)
412	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IEC 60947 (Part 4-1)
413	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IEC 60947 (Part 5-1)
414	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IEC 60947 (Part 5-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 31 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
415	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IEC 60947 (Part 5-1)
416	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IS/IEC 60947 (Part 1)
417	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IS/IEC 60947 (Part 1)
418	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IS/IEC 60947 (Part 1)
419	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IS/IEC 60947 (Part 4-1)
420	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IS/IEC 60947 (Part 4-1)
421	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IS/IEC 60947 (Part 4-1)
422	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IS/IEC 60947 (Part 5-1)
423	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IS/IEC 60947 (Part 5-1)
424	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Conditional short Circuit current	IS/IEC 60947 (Part 5-1)
425	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Degree of protection; Protection against electric shock	IEC 60529
426	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Degree of protection; Protection against electric shock	IEC 60947 (Part 1)
427	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Degree of protection; Protection against electric shock	IEC 60947 (Part 4-1)
428	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Degree of protection; Protection against electric shock	IS/IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	32 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
429	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IEC 60947 (Part 1)
430	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IEC 60947 (Part 1)
431	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IEC 60947 (Part 4-1)
432	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IEC 60947 (Part 4-1)
433	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IEC 60947 (Part 5-1)
434	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IEC 60947 (Part 5-1)
435	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IS/IEC 60947 (Part 1)
436	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IS/IEC 60947 (Part 1)
437	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IS/IEC 60947 (Part 4-1)
438	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IS/IEC 60947 (Part 4-1)
439	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IS/IEC 60947 (Part 5-1)
440	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric properties	IS/IEC 60947 (Part 5-1)
441	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Impulse test)	IEC 60947 (Part 1)
442	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Impulse test)	IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	33 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
443	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Impulse test)	IEC 60947 (Part 1)
444	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Impulse test)	IEC 60947 (Part 4-1)
445	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Impulse test)	IEC 60947 (Part 4-1)
446	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Impulse test)	IEC 60947 (Part 4-1)
447	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Impulse test)	IS/IEC 60947 (Part 1)
448	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Impulse test)	IS/IEC 60947 (Part 1)
449	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Impulse test)	IS/IEC 60947 (Part 1)
450	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Impulse test)	IS/IEC 60947 (Part 1)
451	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Impulse test)	IS/IEC 60947 (Part 4-1)
452	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Power frequency voltage withstand test	IEC 60947 (Part 1)
453	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Power frequency voltage withstand test	IEC 60947 (Part 1)
454	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Power frequency voltage withstand test	IEC 60947 (Part 4-1)
455	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Power frequency voltage withstand test	IEC 60947 (Part 4-1)
456	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Power frequency voltage withstand test	IS/IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	34 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
457	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Power frequency voltage withstand test	IS/IEC 60947 (Part 1)
458	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Power frequency voltage withstand test	IS/IEC 60947 (Part 4-1)
459	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dielectric test (Power frequency voltage withstand test	IS/IEC 60947 (Part 4-1)
460	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dry heat	IE 60068 (Part 2-14)
461	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dry heat	IE 60068 (Part 2-14)
462	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dry heat	IEC 60068 (Part 2-30)
463	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dry heat	IEC 60068 (Part 2-30)
464	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dry heat	IEC 60947 (Part 1)
465	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dry heat	IEC 60947 (Part 1)
466	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dry heat	IS/IEC 60947 (Part 1)
467	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dry heat	IS/IEC 60947 (Part 1)
468	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dry heat	IS/IEC 60947 (Part 4-1)
469	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Dry heat	IS/IEC 60947 (Part 4-1)
470	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 35 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
471	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IEC 60947 (Part 1)
472	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IEC 60947 (Part 4-1)
473	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IEC 60947 (Part 4-1)
474	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IEC 60947 (Part 5-1)
475	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IEC 60947 (Part 5-1)
476	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IS/IEC 60947 (Part 1)
477	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IS/IEC 60947 (Part 1)
478	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IS/IEC 60947 (Part 4-1)
479	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IS/IEC 60947 (Part 4-1)
480	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IS/IEC 60947 (Part 5-1)
481	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Electrical endurance	IS/IEC 60947 (Part 5-1)
482	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Environment test Dry heat	IEC 60947 (Part 4-1)
483	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Environment test Dry heat	IEC 60947 (Part 4-1)
484	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Glow wire	IEC 60669 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 36 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
485	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Glow wire	IEC 60695 (Part 2-10)
486	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Glow wire	IEC 60695 (Part 2-11)
487	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Glow wire	IEC 60947 (Part 1)
488	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Glow wire	IS/IEC 60947 (Part 1)
489	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IEC 60947 (Part 1)
490	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IEC 60947 (Part 1)
491	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IEC 60947 (Part 4-1)
492	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IEC 60947 (Part 4-1)
493	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IEC 60947 (Part 5-1)
494	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IEC 60947 (Part 5-1)
495	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IS/IEC 60947 (Part 1)
496	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IS/IEC 60947 (Part 1)
497	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IS/IEC 60947 (Part 4-1)
498	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IS/IEC 60947 (Part 4-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 37 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
499	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IS/IEC 60947 (Part 5-1)
500	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Leakage current	IS/IEC 60947 (Part 5-1)
501	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IEC 60947 (Part 1)
502	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IEC 60947 (Part 1)
503	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IEC 60947 (Part 1)
504	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IEC 60947 (Part 4-1)
505	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IEC 60947 (Part 4-1)
506	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IEC 60947 (Part 4-1)
507	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IEC 60947 (Part 5-1)
508	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IEC 60947 (Part 5-1)
509	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IEC 60947 (Part 5-1)
510	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IS/IEC 60947 (Part 1)
511	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IS/IEC 60947 (Part 1)
512	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IS/IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	38 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
513	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IS/IEC 60947 (Part 4-1)
514	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IS/IEC 60947 (Part 4-1)
515	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Making & breaking capacity	IS/IEC 60947 (Part 4-1)
516	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Mechanical operational performance capability	IEC 60947 (Part 1)
517	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Mechanical operational performance capability	IEC 60947 (Part 4-1)
518	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Mechanical operational performance capability	IS/IEC 60947 (Part 1)
519	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Mechanical operational performance capability	IS/IEC 60947 (Part 4-1)
520	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Moisture and humidity test	IE 60068 (Part 2-14)
521	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Moisture and humidity test	IE 60068 (Part 2-14)
522	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Moisture and humidity test	IEC 60068 (Part 2-30)
523	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Moisture and humidity test	IEC 60068 (Part 2-30)
524	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Moisture and humidity test	IEC 60947 (Part 1)
525	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Moisture and humidity test	IEC 60947 (Part 1)
526	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Moisture and humidity test	IS/IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	39 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
527	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Moisture and humidity test	IS/IEC 60947 (Part 1)
528	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Operation and operating limits	IEC 60947 (Part 1)
529	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Operation and operating limits	IEC 60947 (Part 1)
530	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Operation and operating limits	IEC 60947 (Part 4-1)
531	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Operation and operating limits	IEC 60947 (Part 4-1)
532	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Operation and operating limits	IS/IEC 60947 (Part 1)
533	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Operation and operating limits	IS/IEC 60947 (Part 1)
534	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Operation and operating limits	IS/IEC 60947 (Part 4-1)
535	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Operation and operating limits	IS/IEC 60947 (Part 4-1)
536	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Operational performance	IEC 60947 (Part 1)
537	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Operational performance	IEC 60947 (Part 4-1)
538	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Operational performance	IS/IEC 60947 (Part 4-1)
539	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload performance	IEC 60947 (Part 1)
540	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload performance	IEC 60947 (Part 4-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	40 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
541	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload performance	IS/IEC 60947 (Part 1)
542	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload performance	IS/IEC 60947 (Part 4-1)
543	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload Releases	IEC 60947 (Part 1)
544	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload Releases	IEC 60947 (Part 1)
545	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload Releases	IEC 60947 (Part 4-1)
546	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload Releases	IEC 60947 (Part 4-1)
547	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload Releases	IS/IEC 60947 (Part 1)
548	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload Releases	IS/IEC 60947 (Part 1)
549	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload Releases	IS/IEC 60947 (Part 4-1)
550	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Overload Releases	IS/IEC 60947 (Part 4-1)
551	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IEC 60947 (Part 1)
552	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IEC 60947 (Part 1)
553	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IEC 60947 (Part 1)
554	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IEC 60947 (Part 4-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 41 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
555	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IEC 60947 (Part 4-1)
556	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IEC 60947 (Part 4-1)
557	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IEC 60947 (Part 5-1)
558	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IEC 60947 (Part 5-1)
559	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IEC 60947 (Part 5-1)
560	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IS/IEC 60947 (Part 1)
561	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IS/IEC 60947 (Part 1)
562	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IS/IEC 60947 (Part 1)
563	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IS/IEC 60947 (Part 4-1)
564	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IS/IEC 60947 (Part 4-1)
565	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IS/IEC 60947 (Part 4-1)
566	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IS/IEC 60947 (Part 5-1)
567	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IS/IEC 60947 (Part 5-1)
568	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Performance under short circuit conditions	IS/IEC 60947 (Part 5-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	42 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
569	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IEC 60947 (Part 1)
570	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IEC 60947 (Part 1)
571	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IEC 60947 (Part 1)
572	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IEC 60947 (Part 1)
573	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IEC 60947 (Part 4-1)
574	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IEC 60947 (Part 4-1)
575	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IEC 60947 (Part 4-1)
576	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IEC 60947 (Part 5-1)
577	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IEC 60947 (Part 5-1)
578	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IS/IEC 60947 (Part 1)
579	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IS/IEC 60947 (Part 1)
580	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IS/IEC 60947 (Part 1)
581	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IS/IEC 60947 (Part 4-1)
582	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IS/IEC 60947 (Part 4-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	43 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
583	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IS/IEC 60947 (Part 4-1)
584	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IS/IEC 60947 (Part 5-1)
585	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IS/IEC 60947 (Part 5-1)
586	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Short circuit making capacity	IS/IEC 60947 (Part 5-1)
587	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IEC 60947 (Part 1)
588	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IEC 60947 (Part 1)
589	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IEC 60947 (Part 4-1)
590	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IEC 60947 (Part 4-1)
591	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IEC 60947 (Part 5-1)
592	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IEC 60947 (Part 5-1)
593	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IS/IEC 60947 (Part 1)
594	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IS/IEC 60947 (Part 1)
595	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IS/IEC 60947 (Part 4-1)
596	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IS/IEC 60947 (Part 4-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 44 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
597	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IS/IEC 60947 (Part 5-1)
598	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Temperature rise	IS/IEC 60947 (Part 5-1)
599	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of ability to withstand overload current	IEC 60947 (Part 1)
600	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of ability to withstand overload current	IEC 60947 (Part 1)
601	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of ability to withstand overload current	IEC 60947 (Part 4-1)
602	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of ability to withstand overload current	IEC 60947 (Part 4-1)
603	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of ability to withstand overload current	IS/IEC 60947 (Part 1)
604	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of ability to withstand overload current	IS/IEC 60947 (Part 1)
605	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of ability to withstand overload current	IS/IEC 60947 (Part 4-1)
606	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of ability to withstand overload current	IS/IEC 60947 (Part 4-1)
607	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of conventional operational performance	IEC 60947 (Part 1)
608	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of conventional operational performance	IEC 60947 (Part 4-1)
609	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of conventional operational performance	IS/IEC 60947 (Part 1)
610	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of conventional operational performance	IS/IEC 60947 (Part 4-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 45 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
611	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of main contact position	IEC 60947 (Part 1)
612	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of main contact position	IEC 60947 (Part 4-1)
613	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of main contact position	IS/IEC 60947 (Part 1)
614	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of main contact position	IS/IEC 60947 (Part 4-1)
615	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60947 (Part 1)
616	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60947 (Part 4-1)
617	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60947 (Part 5-1)
618	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS/IEC 60947 (Part 1)
619	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS/IEC 60947 (Part 5-1)
620	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IEC 60947 (Part 1)
621	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 46 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
622	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IEC 60947 (Part 1)
623	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IEC 60947 (Part 4-1)
624	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IEC 60947 (Part 4-1)
625	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IEC 60947 (Part 4-1)
626	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IEC 60947 (Part 5-1)
627	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IEC 60947 (Part 5-1)
628	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IEC 60947 (Part 5-1)
629	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IS/IEC 60947 (Part 1)
630	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IS/IEC 60947 (Part 1)
631	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IS/IEC 60947 (Part 1)
632	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IS/IEC 60947 (Part 4-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 47 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
633	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IS/IEC 60947 (Part 4-1)
634	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IS/IEC 60947 (Part 4-1)
635	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IS/IEC 60947 (Part 5-1)
636	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IS/IEC 60947 (Part 5-1)
637	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Motor starters and Contactors	Verification of rated making and breaking capacities, change over ability and reversibility	IS/IEC 60947 (Part 5-1)
638	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IE 60068 (Part 2-14)
639	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IE 60068 (Part 2-14)
640	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IEC 60068 (Part 2-30)
641	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IEC 60068 (Part 2-30)
642	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IEC 60947 (Part 5-2)
643	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IEC 60947 (Part 5-2)
644	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IEC 60947 (Part 5-4)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 48 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
645	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IEC 60947 (Part 5-4)
646	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IEC 60947 (Part 6-1)
647	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IEC 60947 (Part 6-1)
648	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IS/IEC 60947 (Part 5-2)
649	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IS/IEC 60947 (Part 5-2)
650	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Clearances and creepage Distances	IEC 60947 (Part 5-2)
651	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Clearances and creepage Distances	IEC 60947 (Part 6-1)
652	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Clearances and creepage Distances	IS/IEC 60947 (Part 5-2)
653	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Conditional short Circuit current	IEC 60947 (Part 5-2)
654	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Conditional short Circuit current	IEC 60947 (Part 5-2)
655	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Conditional short Circuit current	IEC 60947 (Part 5-2)
656	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Conditional short Circuit current	IEC 60947 (Part 6-1)
657	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Conditional short Circuit current	IEC 60947 (Part 6-1)
658	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Conditional short Circuit current	IEC 60947 (Part 6-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	49 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
659	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Conditional short Circuit current	IS/IEC 60947 (Part 5-2)
660	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Conditional short Circuit current	IS/IEC 60947 (Part 5-2)
661	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Conditional short Circuit current	IS/IEC 60947 (Part 5-2)
662	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Degree of protection; Protection against electric shock	IEC 60529
663	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric properties	IEC 60947 (Part 5-2)
664	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric properties	IEC 60947 (Part 5-2)
665	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric properties	IEC 60947 (Part 6-1)
666	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric properties	IEC 60947 (Part 6-1)
667	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric properties	IS/IEC 60947 (Part 5-2)
668	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric properties	IS/IEC 60947 (Part 5-2)
669	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Impulse test)	IEC 60947 (Part 5-2)
670	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Impulse test)	IEC 60947 (Part 5-2)
671	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Impulse test)	IEC 60947 (Part 5-2)
672	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Impulse test)	IEC 60947 (Part 6-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 50 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
673	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Impulse test)	IEC 60947 (Part 6-1)
674	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Impulse test)	IEC 60947 (Part 6-1)
675	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Impulse test)	IEC 60947 (Part 6-1)
676	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Impulse test)	IS/IEC 60947 (Part 5-2)
677	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Impulse test)	IS/IEC 60947 (Part 5-2)
678	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Impulse test)	IS/IEC 60947 (Part 5-2)
679	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 3)
680	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 6-1)
681	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 6-1)
682	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Power frequency voltage withstand test)	IS/IEC 60947 (Part 5-2)
683	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dielectric test (Power frequency voltage withstand test)	IS/IEC 60947 (Part 5-2)
684	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IEC 60068 (Part 2-30)
685	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Dry heat	IEC 60068 (Part 2-30)
686	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Glow wire	IEC 60695 (Part 2-10)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	51 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
687	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Glow wire	IEC 60695 (Part 2-11)
688	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Glow wire	IS/IEC 60947 (Part 1)
689	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Leakage current	IEC 60947 (Part 5-2)
690	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Leakage current	IEC 60947 (Part 5-2)
691	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Leakage current	IEC 60947 (Part 6-1)
692	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Leakage current	IEC 60947 (Part 6-1)
693	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Leakage current	IS/IEC 60947 (Part 5-2)
694	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Leakage current	IS/IEC 60947 (Part 5-2)
695	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Making & breaking capacity	IEC 60947 (Part 1)
696	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Making & breaking capacity	IEC 60947 (Part 1)
697	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Making & breaking capacity	IEC 60947 (Part 1)
698	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Making & breaking capacity	IEC 60947 (Part 6-1)
699	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Making & breaking capacity	IEC 60947 (Part 6-1)
700	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Making & breaking capacity	IEC 60947 (Part 6-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 52 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
701	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Making & breaking capacity	IS/IEC 60947 (Part 1)
702	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Making & breaking capacity	IS/IEC 60947 (Part 1)
703	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Making & breaking capacity	IS/IEC 60947 (Part 1)
704	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Mechanical operational performance capability	IEC 60947 (Part 6-1)
705	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Moisture and humidity test	IE 60068 (Part 2-14)
706	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Moisture and humidity test	IE 60068 (Part 2-14)
707	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Moisture and humidity test	IEC 60068 (Part 2-30)
708	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Moisture and humidity test	IEC 60068 (Part 2-30)
709	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Moisture and humidity test	IEC 60947 (Part 5-2)
710	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Moisture and humidity test	IEC 60947 (Part 5-2)
711	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Moisture and humidity test	IEC 60947 (Part 6-1)
712	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Moisture and humidity test	IS/IEC 60947 (Part 5-2)
713	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Moisture and humidity test	IS/IEC 60947 (Part 5-2)
714	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Operation and operating limits	IEC 60947 (Part 5-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 53 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
715	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Operation and operating limits	IEC 60947 (Part 5-2)
716	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Operation and operating limits	IEC 60947 (Part 6-1)
717	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Operation and operating limits	IEC 60947 (Part 6-1)
718	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Operation and operating limits	IS/IEC 60947 (Part 5-2)
719	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Operation and operating limits	IS/IEC 60947 (Part 5-2)
720	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Operational performance	IEC 60947 (Part 5-2)
721	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Operational performance	IEC 60947 (Part 6-1)
722	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Performance under short circuit conditions	IEC 60947 (Part 5-2)
723	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Performance under short circuit conditions	IEC 60947 (Part 5-2)
724	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Performance under short circuit conditions	IEC 60947 (Part 5-2)
725	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Performance under short circuit conditions	IS/IEC 60947 (Part 5-2)
726	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Performance under short circuit conditions	IS/IEC 60947 (Part 5-2)
727	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Performance under short circuit conditions	IS/IEC 60947 (Part 5-2)
728	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IEC 60947 (Part 5-2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	54 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
729	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IEC 60947 (Part 5-2)
730	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IEC 60947 (Part 5-2)
731	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IEC 60947 (Part 5-4)
732	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IEC 60947 (Part 5-4)
733	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IEC 60947 (Part 5-4)
734	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IEC 60947 (Part 6-1)
735	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IEC 60947 (Part 6-1)
736	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IEC 60947 (Part 6-1)
737	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IS/IEC 60947 (Part 5-2)
738	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IS/IEC 60947 (Part 5-2)
739	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short circuit making capacity	IS/IEC 60947 (Part 5-2)
740	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short time withstand current	IEC 60947 (Part 6-1)
741	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short time withstand current	IEC 60947 (Part 6-1)
742	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Short time withstand current	IEC 60947 (Part 6-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 55 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
743	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Temperature rise	IEC 60947 (Part 5-2)
744	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Temperature rise	IEC 60947 (Part 5-2)
745	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Temperature rise	IEC 60947 (Part 6-1)
746	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Temperature rise	IEC 60947 (Part 6-1)
747	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Temperature rise	IS/IEC 60947 (Part 5-2)
748	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Temperature rise	IS/IEC 60947 (Part 5-2)
749	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Verification of conventional operational performance	IEC 60947 (Part 6-1)
750	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60947 (Part 5-2)
751	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60947 (Part 6-1)
752	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Multiple function equipment, Proximity switches	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS/IEC 60947 (Part 5-2)
753	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61009 (Part 2-2)
754	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61008 (Part 2-1)
755	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	56 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
756	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 1)
757	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 1)
758	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 1)
759	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC/EN 60898 (Part 2)
760	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC/EN 60898 (Part 2)
761	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC/EN 60898 (Part 2)
762	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC/EN 60898 (Part 2)
763	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 1)
764	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 2)
765	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 2)
766	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 2)
767	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 2)
768	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 2)
769	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC/EN 60898 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 57 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
770	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC/EN 60898 (Part 2)
771	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 1)
772	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	28-day testing	IEC 60898 (Part 2)
773	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61008 (Part 1)
774	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61008 (Part 1)
775	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61008 (Part 1)
776	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61008 (Part 2-1)
777	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61008 (Part 2-1)
778	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61008 (Part 2-2)
779	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61008 (Part 2-2)
780	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61008 (Part 2-2)
781	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61009 (Part 1)
782	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61009 (Part 1)
783	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61009 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 58 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
784	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61009 (Part 2-1)
785	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61009 (Part 2-2)
786	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61009 (Part 2-2)
787	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC 61009 (Part 2-2)
788	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC/EN 61008 (Part 1)
789	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC/EN 61008 (Part 1)
790	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC/EN 61009 (Part 1)
791	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC/EN 61009 (Part 1)
792	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IEC/EN 61009 (Part 1)
793	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IS 12640 (Part 1)
794	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IS 12640 (Part 1)
795	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IS 12640 (Part 2)
796	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IS 12640 (Part 2)
797	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Ageing of electronic Component	IS 12640 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 59 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
798	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61008 (Part 1)
799	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61008 (Part 1)
800	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61008 (Part 1)
801	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61008 (Part 2-1)
802	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61008 (Part 2-1)
803	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61008 (Part 2-1)
804	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61008 (Part 2-2)
805	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61008 (Part 2-2)
806	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61008 (Part 2-2)
807	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61009 (Part 1)
808	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61009 (Part 1)
809	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61009 (Part 1)
810	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61009 (Part 2-1)
811	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61009 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 60 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
812	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61009 (Part 2-1)
813	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61009 (Part 2-2)
814	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61009 (Part 2-2)
815	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC 61009 (Part 2-2)
816	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC/EN 61008 (Part 1)
817	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC/EN 61008 (Part 1)
818	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC/EN 61009 (Part 1)
819	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IEC/EN 61009 (Part 1)
820	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IS 12640 (Part 1)
821	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IS 12640 (Part 2)
822	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IS 12640 (Part 2)
823	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of surge currents	IS 12640 (Part 2)
824	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of earth fault current comprising a d.c. component	IEC 61008 (Part 1)
825	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of earth fault current comprising a d.c. component	IEC 61008 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 61 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
826	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of earth fault current comprising a d.c. component	IEC 61008 (Part 2-2)
827	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of earth fault current comprising a d.c. component	IEC 61009 (Part 1)
828	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of earth fault current comprising a d.c. component	IEC 61009 (Part 2-1)
829	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of earth fault current comprising a d.c. component	IEC 61009 (Part 2-2)
830	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of earth fault current comprising a d.c. component	IEC/EN 61008 (Part 1)
831	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of earth fault current comprising a d.c. component	IEC/EN 61009 (Part 1)
832	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour in case of earth fault current comprising a d.c. component	IS 12640 (Part 1)
833	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC 61008 (Part 1)
834	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC 61008 (Part 2-1)
835	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC 61008 (Part 2-1)
836	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC 61008 (Part 2-2)
837	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC 61009 (Part 1)
838	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC 61009 (Part 1)
839	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC 61009 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 62 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
840	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC 61009 (Part 2-2)
841	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC/EN 61008 (Part 1)
842	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC/EN 61008 (Part 1)
843	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC/EN 61009 (Part 1)
844	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC/EN 61009 (Part 1)
845	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IS 12640 (Part 1)
846	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IS 12640 (Part 1)
847	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IS 12640 (Part 2)
848	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IS 12640 (Part 2)
849	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC 61008 (Part 2-1)
850	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC 61008 (Part 2-1)
851	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC 61008 (Part 2-2)
852	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC 61008 (Part 2-2)
853	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC 61009 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 63 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
854	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC 61009 (Part 1)
855	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC 61009 (Part 2-1)
856	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC 61009 (Part 2-1)
857	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC 61009 (Part 2-2)
858	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC 61009 (Part 2-2)
859	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC/EN 61008 (Part 1)
860	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC/EN 61008 (Part 1)
861	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC/EN 61009 (Part 1)
862	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Behaviour of components bridging the basic insulation	IEC/EN 61009 (Part 1)
863	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Capability of control circuits units connected to the main circuits withstanding high d.c. voltages due to insulation measurements	IEC 61008 (Part 2-1)
864	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Capability of control circuits units connected to the main circuits withstanding high d.c. voltages due to insulation measurements	IEC 61008 (Part 2-2)
865	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Capability of control circuits units connected to the main circuits withstanding high d.c. voltages due to insulation measurements	IEC 61009 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 64 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
866	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Capability of control circuits units connected to the main circuits withstanding high d.c. voltages due to insulation measurements	IEC 61009 (Part 2-1)
867	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Capability of control circuits units connected to the main circuits withstanding high d.c. voltages due to insulation measurements	IEC 61009 (Part 2-2)
868	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Capability of control circuits units connected to the main circuits withstanding high d.c. voltages due to insulation measurements	IEC/EN 61008 (Part 1)
869	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Capability of control circuits units connected to the main circuits withstanding high d.c. voltages due to insulation measurements	IEC/EN 61009 (Part 1)
870	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC 60309 (Part 1)
871	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC 60309 (Part 2)
872	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC 60669 (Part 1)
873	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC 60669 (Part 2-1)
874	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC 60898 (Part 1)
875	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC 60898 (Part 2)
876	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC 61008 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 65 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
877	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC 61008 (Part 2-1)
878	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC 61008 (Part 2-2)
879	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC 61009 (Part 2-1)
880	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC 61009 (Part 2-2)
881	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC/EN 60898 (Part 2)
882	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC/EN 61008 (Part 1)
883	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IEC/EN 61009 (Part 1)
884	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IS 12640 (Part 1)
885	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IS 12640 (Part 2)
886	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances and creepage Distances	IS/IEC 60309 (Part 1)
887	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	EC 60898 (Part 1)
888	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	EC 60898 (Part 1)
889	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	EC 60898 (Part 1)
890	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	EC 60898 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	66 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
891	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	EC 60898 (Part 2)
892	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	EC 60898 (Part 2)
893	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61008 (Part 1)
894	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61008 (Part 1)
895	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61008 (Part 1)
896	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61008 (Part 2-1)
897	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61008 (Part 2-1)
898	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61008 (Part 2-1)
899	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61008 (Part 2-2)
900	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61008 (Part 2-2)
901	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61008 (Part 2-2)
902	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61009 (Part 1)
903	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61009 (Part 1)
904	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61009 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 67 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
905	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61009 (Part 2-1)
906	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61009 (Part 2-1)
907	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61009 (Part 2-1)
908	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61009 (Part 2-2)
909	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC 61009 (Part 2-2)
910	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC/EN 60898 (Part 2)
911	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC/EN 60898 (Part 2)
912	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC/EN 60898 (Part 2)
913	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC/EN 61008 (Part 1)
914	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC/EN 61008 (Part 1)
915	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC/EN 61008 (Part 1)
916	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC/EN 61009 (Part 1)
917	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC/EN 61009 (Part 1)
918	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IEC/EN 61009 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	68 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
919	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IS 12640 (Part 1)
920	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IS 12640 (Part 1)
921	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Clearances with the impulse withstand voltage	IS 12640 (Part 1)
922	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61008 (Part 1)
923	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61008 (Part 1)
924	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61008 (Part 2-1)
925	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61008 (Part 2-2)
926	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61008 (Part 2-2)
927	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61009 (Part 1)
928	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61009 (Part 1)
929	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61009 (Part 2-1)
930	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61009 (Part 2-1)
931	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61009 (Part 2-2)
932	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC 61009 (Part 2-2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	69 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
933	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC/EN 61008 (Prat 1)
934	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC/EN 61008 (Prat 1)
935	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC/EN 61009 (Prat 1)
936	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IEC/EN 61009 (Prat 1)
937	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IS 12640 (Part 1)
938	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IS 12640 (Part 1)
939	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IS 12640 (Part 2)
940	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Climatic test	IS 12640 (Part 2)
941	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at I?c	IEC 61008 (Part 1)
942	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at I?c	IEC 61008 (Part 2-1)
943	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at I?c	IEC 61008 (Part 2-2)
944	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at I?c	IEC/EN 61008 (Prat 1)
945	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at Im	IEC 61008 (Part 1)
946	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at Im	IEC 61008 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 70 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
947	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at Im	IEC 61008 (Part 2-2)
948	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at Im	IEC/EN 61008 (Prat 1)
949	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at Inc	IEC 61008 (Part 1)
950	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at Inc	IEC 61008 (Part 2-1)
951	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at Inc	IEC 61008 (Part 2-2)
952	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Coordination at Inc	IEC/EN 61008 (Prat 1)
953	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC 60309 (Part -1)
954	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC 60309 (Part 2)
955	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC 60898 (Part 1)
956	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC 60898 (Part 2)
957	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC 61008 (Part 1)
958	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC 61008 (Part 1)
959	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC 61008 (Part 2-1)
960	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC 61008 (Part 2-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 71 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
961	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC 61009 (Part 1)
962	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC 61009 (Part 2-2)
963	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC/EN 60898 (Part 2)
964	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC/EN 61008 (Prat 1)
965	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IEC/EN 61009 (Prat 1)
966	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IS 12640 (Part 1)
967	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IS 12640 (Part 2)
968	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Degree of protection, Protection against Electric shock	IS/IEC 60309 (Part 1)
969	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 60898 (Part 1)
970	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 60898 (Part 1)
971	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 60898 (Part 2)
972	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 61008 (Part 2-1)
973	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 61008 (Part 2-1)
974	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 61008 (Part 2-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 72 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
975	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 61008 (Part 2-2)
976	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 61009 (Part 1)
977	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 61009 (Part 1)
978	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 61009 (Part 2-1)
979	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 61009 (Part 2-1)
980	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC 61009 (Part 2-2)
981	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC/EN 60898 (Part 2)
982	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC/EN 60898 (Part 2)
983	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC/EN 61009 (Part 1)
984	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IEC/EN 61009 (Part 1)
985	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IS 12640 (Part 1)
986	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Dielectric Strength of main circuit	IS 12640 (Part 1)
987	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IEC 60898 (Part 1)
988	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IEC 60898 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	73 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
989	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IEC 61008 (Part 1)
990	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IEC 61008 (Part 2-1)
991	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IEC 61008 (Part 2-2)
992	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IEC 61009 (Part 1)
993	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IEC 61009 (Part 2-1)
994	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IEC 61009 (Part 2-2)
995	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IEC/EN 60898 (Part 2)
996	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IEC/EN 61008 (Prat 1)
997	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IEC/EN 61009 (Prat 1)
998	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IS 12640 (Part 1)
999	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Glow wire, Resistance to abnormal heat and to fire	IS 12640 (Part 2)
1000	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IEC 60898 (Part 1)
1001	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IEC 60898 (Part 2)
1002	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IEC 61008 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 74 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1003	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IEC 61008 (Part 2-1)
1004	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IEC 61008 (Part 2-2)
1005	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IEC 61009 (Part 1)
1006	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IEC 61009 (Part 2-1)
1007	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IEC 61009 (Part 2-2)
1008	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IEC/EN 60898 (Part 2)
1009	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IEC/EN 61008 (Part 1)
1010	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IEC/EN 61009 (Part 1)
1011	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IS 12640 (Part 1)
1012	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Indelibility of marking	IS 12640 (Part 2)
1013	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance	IEC 60898 (Part 1)
1014	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance	IEC 61008 (Part 1)
1015	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance	IEC 61008 (Part 2-1)
1016	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance	IEC 61008 (Part 2-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 75 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1017	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance	IEC 61009 (Part 1)
1018	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance	IEC 61009 (Part 2-1)
1019	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance	IEC 61009 (Part 2-2)
1020	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance	IEC/EN 61008 (Part 1)
1021	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance	IEC/EN 61009 (Part 1)
1022	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 60898 (Part 1)
1023	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 60898 (Part 1)
1024	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 60898 (Part 1)
1025	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61008 (Part 1)
1026	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61008 (Part 1)
1027	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61008 (Part 1)
1028	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61008 (Part 2-1)
1029	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61008 (Part 2-1)
1030	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61008 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	76 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1031	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61008 (Part 2-2)
1032	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61008 (Part 2-2)
1033	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61008 (Part 2-2)
1034	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61009 (Part 1)
1035	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61009 (Part 1)
1036	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61009 (Part 1)
1037	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61009 (Part 2-1)
1038	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61009 (Part 2-1)
1039	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61009 (Part 2-1)
1040	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61009 (Part 2-2)
1041	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61009 (Part 2-2)
1042	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC 61009 (Part 2-2)
1043	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC/EN 60898 (Part 2)
1044	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC/EN 61008 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 77 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1045	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC/EN 61008 (Part 1)
1046	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC/EN 61009 (Part 1)
1047	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC/EN 61009 (Part 1)
1048	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and dielectric strength of auxiliary circuits	IEC/EN 61009 (Part 1)
1049	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60309 (Part 1)
1050	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60309 (Part 1)
1051	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60309 (Part 1)
1052	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60309 (Part 2)
1053	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60309 (Part 2)
1054	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60309 (Part 2)
1055	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60669 (Part 1)
1056	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60669 (Part 1)
1057	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60669 (Part 1)
1058	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60669 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 78 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1059	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60669 (Part 2-1)
1060	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IEC 60669 (Part 2-1)
1061	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IS 3854
1062	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IS 3854
1063	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IS 3854
1064	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IS/IEC 60309 (Part 1)
1065	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IS/IEC 60309 (Part 1)
1066	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Insulation resistance and electric strength	IS/IEC 60309 (Part 1)
1067	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IEC 60309 (Part 1)
1068	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IEC 60309 (Part 1)
1069	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IEC 60309 (Part 2)
1070	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IEC 60309 (Part 2)
1071	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IEC 60669 (Part 1)
1072	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IEC 60669 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	79 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1073	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IEC 60669 (Part 2-1)
1074	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IEC 60669 (Part 2-1)
1075	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IS 3854
1076	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IS 3854
1077	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IS/IEC 60309 (Part 1)
1078	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Making and breaking capacity	IS/IEC 60309 (Part 1)
1079	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 60898 (Part 1)
1080	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 60898 (Part 2)
1081	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 60898 (Part 2)
1082	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61008 (Part 1)
1083	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61008 (Part 1)
1084	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61008 (Part 2-1)
1085	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61008 (Part 2-1)
1086	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61008 (Part 2-2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	80 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1087	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61008 (Part 2-2)
1088	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61009 (Part 1)
1089	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61009 (Part 1)
1090	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61009 (Part 2-1)
1091	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61009 (Part 2-1)
1092	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61009 (Part 2-2)
1093	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 61009 (Part 2-2)
1094	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC/EN 60898 (Part 2)
1095	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC/EN 60898 (Part 2)
1096	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC/EN 61008 (Prat 1)
1097	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC/EN 61008 (Prat 1)
1098	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC/EN 61009 (Prat 1)
1099	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC/EN 61009 (Prat 1)
1100	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IS 12640 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	81 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1101	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IS 12640 (Part 1)
1102	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IS 12640 (Part 2)
1103	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IS 12640 (Part 2)
1104	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanical and electrical endurance	IEC 60898 (Part 1)
1105	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IEC 60669 (Part 1)
1106	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IEC 60898 (Part 1)
1107	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IEC 60898 (Part 2)
1108	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IEC 61008 (Part 1)
1109	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IEC 61008 (Part 2-1)
1110	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IEC 61008 (Part 2-2)
1111	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IEC 61009 (Part 1)
1112	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IEC 61009 (Part 2-1)
1113	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IEC/EN 60898 (Part 2)
1114	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IEC/EN 61008 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 82 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1115	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IEC/EN 61009 (Part 1)
1116	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Mechanism/ Trip free mechanism	IS 12640 (Part 1)
1117	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC 60898 (Part 1)
1118	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC 60898 (Part 1)
1119	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC 60898 (Part 2)
1120	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC 60898 (Part 2)
1121	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC 61008 (Part 2-1)
1122	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC 61009 (Part 2-1)
1123	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC 61009 (Part 2-1)
1124	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC 61009 (Part 2-2)
1125	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC 61009 (Part 2-2)
1126	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC/EN 60898 (Part 2)
1127	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC/EN 60898 (Part 2)
1128	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC/EN 61009 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	83 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1129	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IEC/EN 61009 (Part 1)
1130	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IS 12640 (Part 1)
1131	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non Interchangeability	IS 12640 (Part 1)
1132	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non operating current under overcurrent conditions	IEC 61008 (Part 1)
1133	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non operating current under overcurrent conditions	IEC 61008 (Part 2-1)
1134	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non operating current under overcurrent conditions	IEC 61008 (Part 2-2)
1135	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non operating current under overcurrent conditions	IEC 61009 (Part 2-2)
1136	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non operating current under overcurrent conditions	IEC 61009 (Part2-1)
1137	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non operating current under overcurrent conditions	IEC/EN 60898 (Part 2)
1138	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Non operating current under overcurrent conditions	IEC/EN 61008 (Prat 1)
1139	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60309 (Part -1)
1140	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60309 (Part -1)
1141	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60309 (Part -1)
1142	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60309 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	84 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1143	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60309 (Part 2)
1144	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60309 (Part 2)
1145	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60669 (Part 1)
1146	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60669 (Part 1)
1147	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60669 (Part 1)
1148	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60669 (Part 2-1)
1149	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60669 (Part 2-1)
1150	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IEC 60669 (Part 2-1)
1151	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IS 3854
1152	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IS 3854
1153	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IS 3854
1154	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IS/IEC 60309 (Part 1)
1155	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IS/IEC 60309 (Part 1)
1156	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Normal operation	IS/IEC 60309 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	85 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1157	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC 61009 (Part 1)
1158	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC 61009 (Part 1)
1159	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC 61009 (Part 1)
1160	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC 61009 (Part 2-1)
1161	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC 61009 (Part 2-1)
1162	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC 61009 (Part 2-1)
1163	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC 61009 (Part 2-2)
1164	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC 61009 (Part 2-2)
1165	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC 61009 (Part 2-2)
1166	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC/EN 61009 (Part 1)
1167	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC/EN 61009 (Part 1)
1168	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IEC/EN 61009 (Prat 1)
1169	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IS 12640 (Part 1)
1170	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IS 12640 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	86 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1171	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IS 12640 (Part 1)
1172	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IS 12640 (Part 2)
1173	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IS 12640 (Part 2)
1174	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Overcurrent operating characteristics	IS 12640 (Part 2)
1175	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 60898 (Part 1)
1176	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 60898 (Part 1)
1177	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 61008 (Part 1)
1178	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 61008 (Part 1)
1179	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 61008 (Part 2-1)
1180	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 61008 (Part 2-1)
1181	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 61008 (Part 2-2)
1182	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 61008 (Part 2-2)
1183	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 61009 (Part 1)
1184	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 61009 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	87 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1185	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 61009 (Part 2-1)
1186	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 61009 (Part 2-1)
1187	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC 61009 (Part 2-2)
1188	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC/EN 60898 (Part 2)
1189	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC/EN 60898 (Part 2)
1190	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC/EN 61008 (Prat 1)
1191	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC/EN 61008 (Prat 1)
1192	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC/EN 61009 (Prat 1)
1193	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at I?m	IEC/EN 61009 (Prat 1)
1194	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at Im	IEC 61008 (Part 1)
1195	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at Im	IEC 61008 (Part 2-1)
1196	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at Im	IEC 61008 (Part 2-2)
1197	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at Im	IEC 61009 (Part 2-2)
1198	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at Im	IEC/EN 60898 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	88 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1199	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at Im	IEC/EN 61008 (Prat 1)
1200	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IEC 60309 (Part 1)
1201	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IEC 60309 (Part 2)
1202	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IEC 60898 (Part 1)
1203	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IEC 60898 (Part 2)
1204	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IEC 61009 (Part 1)
1205	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IEC 61009 (Part 2-1)
1206	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IEC 61009 (Part 2-2)
1207	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IEC/EN 60898 (Part 2)
1208	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IEC/EN 61009 (Prat 1)
1209	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IS 12640 (Part 1)
1210	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IS 12640 (Part 2)
1211	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at rated short circuit capacity	IS/IEC 60309 (Part 1)
1212	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at reduced short circuit currents	IEC 60898 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 89 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1213	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at reduced short circuit currents	IEC 60898 (Part 2)
1214	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at reduced short circuit currents	IEC 61009 (Part 1)
1215	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at reduced short circuit currents	IEC 61009 (Part 2-1)
1216	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at reduced short circuit currents	IEC 61009 (Part 2-2)
1217	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at reduced short circuit currents	IEC/EN 61009 (Prat 1)
1218	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at reduced short circuit currents	IS 12640 (Part 1)
1219	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance at reduced short circuit currents	IS 12640 (Part 2)
1220	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 60898 (Part 1)
1221	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 60898 (Part 1)
1222	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61008 (Part 1)
1223	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61008 (Part 1)
1224	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61008 (Part 2-1)
1225	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61008 (Part 2-1)
1226	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61008 (Part 2-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 90 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1227	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61008 (Part 2-2)
1228	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61009 (Part 1)
1229	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61009 (Part 1)
1230	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61009 (Part 2-1)
1231	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61009 (Part 2-1)
1232	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61009 (Part 2-2)
1233	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC 61009 (Part 2-2)
1234	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC/EN 61008 (Prat 1)
1235	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC/EN 61008 (Prat 1)
1236	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC/EN 61009 (Prat 1)
1237	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IEC/EN 61009 (Prat 1)
1238	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IS 12640 (Part 1)
1239	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Performance of test device	IS 12640 (Part 1)
1240	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 60309 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 91 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1241	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 60309 (Part 2)
1242	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 60669 (Part 1)
1243	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 60669 (Part 2-1)
1244	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 60898 (Part 1)
1245	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 60898 (Part 2)
1246	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 61008 (Part 1)
1247	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 61008 (Part 2-1)
1248	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 61008 (Part 2-2)
1249	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 61009 (Part 1)
1250	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 61009 (Part 2-1)
1251	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC 61009 (Part 2-2)
1252	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC/EN 60898 (Part 2)
1253	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC/EN 61008 (Part 1)
1254	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IEC/EN 61009 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 92 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1255	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IS 12640 (Part 1)
1256	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IS 12640 (Part 2)
1257	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Protection against electric shock	IS/IEC 60309 (Part 1)
1258	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Provision for earthing	IEC 60309 (Part -1)
1259	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Provision for earthing	IEC 60309 (Part -1)
1260	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Provision for earthing	IEC 60309 (Part 2)
1261	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Provision for earthing	IEC 60309 (Part 2)
1262	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Provision for earthing	IEC 60669 (Part 1)
1263	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Provision for earthing	IEC 60669 (Part 1)
1264	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Provision for earthing	IEC 60669 (Part 2-1)
1265	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Provision for earthing	IEC 60669 (Part 2-1)
1266	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Provision for earthing	IS/IEC 60309 (Part 1)
1267	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Provision for earthing	IS/IEC 60309 (Part 1)
1268	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61008 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	93 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1269	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61008 (Part 1)
1270	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61008 (Part 1)
1271	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61008 (Part 2-1)
1272	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61008 (Part 2-1)
1273	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61008 (Part 2-2)
1274	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61008 (Part 2-2)
1275	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61008 (Part 2-2)
1276	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61009 (Part 1)
1277	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61009 (Part 1)
1278	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61009 (Part 1)
1279	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61009 (Part 2-1)
1280	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61009 (Part 2-1)
1281	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61009 (Part 2-1)
1282	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61009 (Part 2-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 94 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1283	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61009 (Part 2-2)
1284	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC 61009 (Part 2-2)
1285	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC/EN 61008 (Part 1)
1286	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC/EN 61008 (Part 1)
1287	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC/EN 61008 (Part 1)
1288	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC/EN 61009 (Part 1)
1289	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC/EN 61009 (Part 1)
1290	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IEC/EN 61009 (Part 1)
1291	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IS 12640 (Part 1)
1292	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IS 12640 (Part 1)
1293	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IS 12640 (Part 1)
1294	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IS 12640 (Part 2)
1295	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IS 12640 (Part 2)
1296	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability	IS 12640 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 95 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1297	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60309 (Part 1)
1298	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60309 (Part 1)
1299	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60309 (Part 2)
1300	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60309 (Part 2)
1301	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60669 (Part 1)
1302	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60669 (Part 1)
1303	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60669 (Part 2-1)
1304	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60669 (Part 2-1)
1305	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60898 (Part 1)
1306	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60898 (Part 1)
1307	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60898 (Part 2)
1308	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 60898 (Part 2)
1309	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61008 (Part 1)
1310	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61008 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	96 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1311	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61008 (Part 2-1)
1312	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61008 (Part 2-2)
1313	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61008 (Part 2-2)
1314	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61009 (Part 1)
1315	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61009 (Part 1)
1316	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61009 (Part 2-1)
1317	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61009 (Part 2-1)
1318	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61009 (Part 2-2)
1319	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61009 (Part 2-2)
1320	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC/EN 60898 (Part 2)
1321	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC/EN 60898 (Part 2)
1322	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC/EN 61008 (Part 1)
1323	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC/EN 61008 (Part 1)
1324	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC/EN 61009 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 97 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1325	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IEC/EN 61009 (Part 1)
1326	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IS 12640 (Part 1)
1327	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IS 12640 (Part 2)
1328	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IS 12640 (Part 2)
1329	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IS/IEC 60309 (Part 1)
1330	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of screws, current carrying parts and connectors	IS/IEC 60309 (Part 1)
1331	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60309 (Part 1)
1332	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60309 (Part 1)
1333	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60309 (Part 1)
1334	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60309 (Part -1)
1335	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60309 (Part -1)
1336	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60309 (Part 2)
1337	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60309 (Part 2)
1338	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60309 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 98 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1339	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60669 (Part 1)
1340	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60669 (Part 1)
1341	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60669 (Part 1)
1342	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60669 (Part 2-1)
1343	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60669 (Part 2-1)
1344	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60669 (Part 2-1)
1345	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60898 (Part 1)
1346	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60898 (Part 1)
1347	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60898 (Part 1)
1348	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60898 (Part 2)
1349	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60898 (Part 2)
1350	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 60898 (Part 2)
1351	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61008 (Part 1)
1352	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61008 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 99 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1353	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61008 (Part 1)
1354	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61008 (Part 2-1)
1355	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61008 (Part 2-1)
1356	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61008 (Part 2-1)
1357	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61008 (Part 2-2)
1358	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61008 (Part 2-2)
1359	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61008 (Part 2-2)
1360	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61009 (Part 1)
1361	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61009 (Part 1)
1362	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61009 (Part 1)
1363	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61009 (Part 2-1)
1364	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61009 (Part 2-1)
1365	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61009 (Part 2-1)
1366	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61009 (Part 2-2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	100 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1367	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61009 (Part 2-2)
1368	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC 61009 (Part 2-2)
1369	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC/EN 60898 (Part 2)
1370	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC/EN 60898 (Part 2)
1371	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC/EN 61008 (Part 2)
1372	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC/EN 61009 (Prat 1)
1373	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC/EN 61009 (Prat 1)
1374	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IEC/EN 61009 (Prat 1)
1375	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IS 12640 (Part 1)
1376	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IS 12640 (Part 1)
1377	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IS 12640 (Part 1)
1378	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IS 12640 (Part 2)
1379	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IS 12640 (Part 2)
1380	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IS 12640 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	101 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1381	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IS/IEC 60309 (Part 1)
1382	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IS/IEC 60309 (Part 1)
1383	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Reliability of terminals for external conductors	IS/IEC 60309 (Part 1)
1384	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61008 (Part 2-1)
1385	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61008 (Part 2-1)
1386	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61008 (Part 2-1)
1387	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61008 (Part 2-2)
1388	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61008 (Part 2-2)
1389	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61008 (Part 2-2)
1390	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61009 (Part 1)
1391	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61009 (Part 1)
1392	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61009 (Part 2-1)
1393	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61009 (Part 2-1)
1394	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61009 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 102 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1395	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61009 (Part 2-2)
1396	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61009 (Part 2-2)
1397	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC 61009 (Part 2-2)
1398	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC/EN 61008 (Part 1)
1399	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC/EN 61008 (Part 1)
1400	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC/EN 61008 (Part 1)
1401	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC/EN 61009 (Part 1)
1402	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC/EN 61009 (Part 1)
1403	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IEC/EN 61009 (Part 1)
1404	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IS 12640 (Part 1)
1405	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IS 12640 (Part 1)
1406	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Residual operating characteristic	IS 12640 (Part 1)
1407	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61008 (Part 1)
1408	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61008 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 103 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1409	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61008 (Part 1)
1410	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61008 (Part 2-1)
1411	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61008 (Part 2-1)
1412	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61008 (Part 2-1)
1413	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61008 (Part 2-2)
1414	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61008 (Part 2-2)
1415	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61008 (Part 2-2)
1416	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61009 (Part 1)
1417	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61009 (Part 1)
1418	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61009 (Part 1)
1419	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61009 (Part 2-1)
1420	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61009 (Part 2-1)
1421	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61009 (Part 2-1)
1422	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61009 (Part 2-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 104 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1423	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61009 (Part 2-2)
1424	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC 61009 (Part 2-2)
1425	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC/EN 61008 (Prat 1)
1426	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC/EN 61008 (Prat 1)
1427	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC/EN 61008 (Prat 1)
1428	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC/EN 61009 (Prat 1)
1429	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC/EN 61009 (Prat 1)
1430	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IEC/EN 61009 (Prat 1)
1431	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IS 12640 (Part 1)
1432	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IS 12640 (Part 1)
1433	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IS 12640 (Part 1)
1434	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IS 12640 (Part 2)
1435	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IS 12640 (Part 2)
1436	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance against unwanted tripping due to current surges	IS 12640 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 105 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1437	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	EC 60309 (Part 1)
1438	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	EC 60309 (Part -1)
1439	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	IEC 60309 (Part 2)
1440	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	IEC 60309 (Part 2)
1441	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	IEC 60669 (Part 1)
1442	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	IEC 60669 (Part 1)
1443	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	IEC 60669 (Part 2-1)
1444	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	IEC 60669 (Part 2-1)
1445	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	IS 3854
1446	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	IS 3854
1447	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	IS/IEC 60309 (Part 1)
1448	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulating material to abnormal heat, to fire and to tracking	IS/IEC 60309 (Part 1)
1449	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 60898 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	106 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1450	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 60898 (Part 1)
1451	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 60898 (Part 1)
1452	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61008 (Part 1)
1453	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61008 (Part 1)
1454	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61008 (Part 1)
1455	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61008 (Part 2-1)
1456	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61008 (Part 2-1)
1457	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61008 (Part 2-1)
1458	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61008 (Part 2-2)
1459	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61008 (Part 2-2)
1460	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61008 (Part 2-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 107 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1461	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61009
1462	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61009 (Part 1)
1463	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61009 (Part 1)
1464	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61009 (Part 1)
1465	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61009 (Part 2-2)
1466	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61009 (Part 2-2)
1467	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61009 (Part 2-2)
1468	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61009 (Part2-1)
1469	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC 61009 (Part2-1)
1470	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC/EN 61008 (Prat 1)
1471	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC/EN 61008 (Prat 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 108 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1472	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC/EN 61008 (Prat 1)
1473	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC/EN 61009 (Prat 1)
1474	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC/EN 61009 (Prat 1)
1475	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IEC/EN 61009 (Prat 1)
1476	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IS 12640 (Part 1)
1477	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IS 12640 (Part 1)
1478	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IS 12640 (Part 1)
1479	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IS 12640 (Part 12)
1480	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IS 12640 (Part 12)
1481	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance of insulation of open contacts and basic insulation against an impulse voltage	IS 12640 (Part 12)
1482	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IEC 60898 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 109 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1483	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IEC 60898 (Part 2)
1484	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IEC 61008 (Part 1)
1485	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IEC 61008 (Part 2-1)
1486	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IEC 61008 (Part 2-2)
1487	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IEC 61009 (Part 1)
1488	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IEC 61009 (Part 2-1)
1489	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IEC 61009 (Part 2-2)
1490	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IEC/EN 61008 (Part 1)
1491	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IEC/EN 61009 (Part 1)
1492	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IS 12640 (Part 1)
1493	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to abnormal heat and to fire	IS 12640 (Part 2)
1494	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60309 (Part -1)
1495	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60309 (Part -1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	110 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1496	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60309 (Part -1)
1497	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60309 (Part 2)
1498	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60309 (Part 2)
1499	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60309 (Part 2)
1500	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60669 (Part 1)
1501	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60669 (Part 1)
1502	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60669 (Part 1)
1503	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60669 (Part 2-1)
1504	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60669 (Part 2-1)
1505	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IEC 60669 (Part 2-1)
1506	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IS/IEC 60309 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 111 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1507	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IS/IEC 60309 (Part 1)
1508	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	IS/IEC 60309 (Part 1)
1509	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60669 (Part 1)
1510	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60669 (Part 1)
1511	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60669 (Part 1)
1512	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60669 (Part 2-1)
1513	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60669 (Part 2-1)
1514	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60669 (Part 2-1)
1515	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60898 (Part 1)
1516	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60898 (Part 1)
1517	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60898 (Part 1)
1518	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60898 (Part 2)
1519	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60898 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 112 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1520	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 60898 (Part 2)
1521	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61008 (Part 1)
1522	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61008 (Part 1)
1523	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61008 (Part 1)
1524	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61008 (Part 2-1)
1525	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61008 (Part 2-1)
1526	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61008 (Part 2-1)
1527	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61008 (Part 2-2)
1528	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61008 (Part 2-2)
1529	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61008 (Part 2-2)
1530	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61009 (Part 1)
1531	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61009 (Part 1)
1532	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61009 (Part 1)
1533	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61009 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	113 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1534	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61009 (Part 2-1)
1535	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61009 (Part 2-1)
1536	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61009 (Part 2-2)
1537	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61009 (Part 2-2)
1538	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC 61009 (Part 2-2)
1539	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC/EN 60898 (Part 2)
1540	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC/EN 60898 (Part 2)
1541	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC/EN 60898 (Part 2)
1542	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC/EN 61008 (Prat 1)
1543	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC/EN 61008 (Prat 1)
1544	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC/EN 61008 (Prat 1)
1545	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC/EN 61009 (Prat 1)
1546	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC/EN 61009 (Prat 1)
1547	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IEC/EN 61009 (Prat 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	114 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1548	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IS 12640 (Part 1)
1549	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IS 12640 (Part 1)
1550	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IS 12640 (Part 1)
1551	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IS 12640 (Part 2)
1552	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IS 12640 (Part 2)
1553	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IS 12640 (Part 2)
1554	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IS 3854
1555	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IS 3854
1556	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to heat	IS 3854
1557	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IEC 60669 (Part 1)
1558	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IEC 60669 (Part 2-1)
1559	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IEC 60898 (Part 1)
1560	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IEC 61008 (Part 1)
1561	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IEC 61008 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	115 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1562	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IEC 61008 (Part 2-2)
1563	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IEC 61009 (Part 1)
1564	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IEC 61009 (Part 2-1)
1565	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IEC 61009 (Part 2-2)
1566	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IEC/EN 61008 (Part 1)
1567	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IEC/EN 61009 (Part 1)
1568	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IS 12640 (Part 1)
1569	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to mechanical shock and impact	IS 12640 (Part 2)
1570	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 60309 (Part -1)
1571	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 60309 (Part -1)
1572	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 60309 (Part 2)
1573	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 60309 (Part 2)
1574	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 60669 (Part 1)
1575	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 60669 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 116 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1576	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 60669 (Part 2-1)
1577	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 60898 (Part 1)
1578	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 60898 (Part 1)
1579	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 60898 (Part 2)
1580	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 60898 (Part 2)
1581	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61008 (Part 1)
1582	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61008 (Part 1)
1583	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61008 (Part 2-1)
1584	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61008 (Part 2-1)
1585	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61008 (Part 2-2)
1586	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61008 (Part 2-2)
1587	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61009 (Part 1)
1588	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61009 (Part 1)
1589	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61009 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 117 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1590	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61009 (Part 2-1)
1591	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61009 (Part 2-2)
1592	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC 61009 (Part 2-2)
1593	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC/EN 60898 (Part 2)
1594	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC/EN 60898 (Part 2)
1595	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC/EN 61008 (Prat 1)
1596	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC/EN 61008 (Prat 1)
1597	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC/EN 61009 (Prat 1)
1598	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IEC/EN 61009 (Prat 1)
1599	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IS 3854
1600	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IS 3854
1601	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IS/IEC 60309 (Part 1)
1602	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Resistance to rusting / humidity	IS/IEC 60309 (Part 1)
1603	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Secondary circuit detection transformers	IEC 61008 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 118 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1604	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Secondary circuit detection transformers	IEC 61008 (Part 2-2)
1605	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Secondary circuit detection transformers	IEC 61009 (Part 1)
1606	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Secondary circuit detection transformers	IEC 61009 (Part 2-1)
1607	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Secondary circuit detection transformers	IEC 61009 (Part 2-2)
1608	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Secondary circuit detection transformers	IEC/EN 61008 (Part 1)
1609	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Secondary circuit detection transformers	IEC/EN 61009 (Part 1)
1610	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Service short circuit capacity	IEC 60898 (Part 1)
1611	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Service short circuit capacity	IEC 60898 (Part 2)
1612	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Service short circuit capacity	IEC 61009 (Part 1)
1613	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Service short circuit capacity	IEC 61009 (Part 2-1)
1614	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Service short circuit capacity	IEC/EN 60898 (Part 2)
1615	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Service short circuit capacity	IEC/EN 61009 (Prat 1)
1616	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Service short circuit capacity	IS 12640 (Part 1)
1617	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Service short circuit capacity	IS 12640 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 119 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1618	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short circuit Performance at 1500A	IEC 60898 (Part 1)
1619	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short circuit Performance at 1500A	IEC 60898 (Part 2)
1620	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short circuit Performance at 1500A	IS 12640 (Part 1)
1621	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short circuit Performance at 1500A	IS 12640 (Part 2)
1622	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short Circuit test for verifying the suitability of circuit breakers for use in IT	IEC 60898 (Part 1)
1623	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short Circuit test for verifying the suitability of circuit breakers for use in IT	IEC 60898 (Part 2)
1624	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short Circuit test for verifying the suitability of circuit breakers for use in IT	IEC 61008 (Part 1)
1625	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short Circuit test for verifying the suitability of circuit breakers for use in IT	IEC 61008 (Part 2-1)
1626	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short Circuit test for verifying the suitability of circuit breakers for use in IT	IEC 61008 (Part 2-2)
1627	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short Circuit test for verifying the suitability of circuit breakers for use in IT	IEC 61009 (Part 2-1)
1628	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short Circuit test for verifying the suitability of circuit breakers for use in IT	IEC 61009 (Part 2-2)
1629	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short Circuit test for verifying the suitability of circuit breakers for use in IT	IEC/EN 60898 (Part 2)
1630	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short Circuit test for verifying the suitability of circuit breakers for use in IT	IEC/EN 61008 (Prat 1)
1631	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Short Circuit test for verifying the suitability of circuit breakers for use in IT	IEC/EN 61009 (Prat 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 120 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1632	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Switch and isolator in case of failure of the line voltage	IEC 61008 (Part 2-2)
1633	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60309 (Part 1)
1634	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60309 (Part 1)
1635	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60309 (Part 1)
1636	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60309 (Part 2)
1637	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60309 (Part 2)
1638	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60309 (Part 2)
1639	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60669 (Part 1)
1640	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60669 (Part 2-1)
1641	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60669 (Part 2-1)
1642	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60669 (Part 2-1)
1643	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60898 (Part 1)
1644	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60898 (Part 1)
1645	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60898 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 121 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1646	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60898 (Part 2)
1647	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60898 (Part 2)
1648	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 60898 (Part 2)
1649	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61008 (Part 1)
1650	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61008 (Part 1)
1651	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61008 (Part 1)
1652	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61008 (Part 2-1)
1653	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61008 (Part 2-1)
1654	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61008 (Part 2-1)
1655	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61008 (Part 2-2)
1656	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61008 (Part 2-2)
1657	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61008 (Part 2-2)
1658	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61009 (Part 1)
1659	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61009 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 122 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1660	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61009 (Part 1)
1661	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61009 (Part 2-1)
1662	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61009 (Part 2-1)
1663	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61009 (Part 2-2)
1664	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61009 (Part 2-2)
1665	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC 61009 (Part 2-2)
1666	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC/EN 60898 (Part 2)
1667	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC/EN 60898 (Part 2)
1668	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC/EN 60898 (Part 2)
1669	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC/EN 61008 (Part 1)
1670	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC/EN 61008 (Part 1)
1671	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC/EN 61008 (Part 1)
1672	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IEC/EN 61009 (Part 2-1)
1673	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS 12640 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 123 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1674	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS 12640 (Part 1)
1675	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS 12640 (Part 1)
1676	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS 12640 (Part 2)
1677	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS 12640 (Part 2)
1678	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS 12640 (Part 2)
1679	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS 3854
1680	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS 3854
1681	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS 3854
1682	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS/IEC 60309 (Part 1)
1683	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS/IEC 60309 (Part 1)
1684	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Temperature Rise and power loss	IS/IEC 60309 (Part 1)
1685	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Tripping characteristic	IEC 60898 (Part 1)
1686	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Tripping characteristic	IEC 60898 (Part 1)
1687	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Tripping characteristic	IEC 60898 (Part 2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 124 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1688	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Tripping characteristic	IEC 60898 (Part 2)
1689	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Tripping characteristic	IEC/EN 60898 (Part 2)
1690	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Tripping characteristic	IEC/EN 60898 (Part 2)
1691	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC 61008 (Part 1)
1692	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC 61008 (Part 1)
1693	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC 61008 (Part 1)
1694	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC 61008 (Part 2-1)
1695	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC 61008 (Part 2-1)
1696	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC 61008 (Part 2-1)
1697	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC 61008 (Part 2-2)
1698	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC 61008 (Part 2-2)
1699	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC 61008 (Part 2-2)
1700	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC/EN 61008 (Part 1)
1701	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC/EN 61008 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 125 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1702	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Unwanted tripping	IEC/EN 61008 (Part 1)
1703	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 60898 (Part 1)
1704	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 60898 (Part 1)
1705	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 60898 (Part 1)
1706	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 60898 (Part 1)
1707	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 60898 (Part 2)
1708	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 60898 (Part 2)
1709	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 60898 (Part 2)
1710	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 60947 (Part 2)
1711	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 61009 (Part 1)
1712	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 61009 (Part 1)
1713	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 61009 (Part 1)
1714	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 61009 (Part 2-1)
1715	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 61009 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 126 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1716	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 61009 (Part 2-1)
1717	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 61009 (Part 2-1)
1718	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 61009 (Part 2-2)
1719	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 61009 (Part 2-2)
1720	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 61009 (Part 2-2)
1721	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC 61009 (Part 2-2)
1722	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC/EN 60898 (Part 2)
1723	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC/EN 60898 (Part 2)
1724	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC/EN 60898 (Part 2)
1725	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC/EN 60898 (Part 2)
1726	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC/EN 61009 (Prat 1)
1727	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC/EN 61009 (Prat 1)
1728	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC/EN 61009 (Prat 1)
1729	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IEC/EN 61009 (Prat 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 127 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1730	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IS 12640 (Part 1)
1731	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IS 12640 (Part 1)
1732	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IS 12640 (Part 1)
1733	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IS 12640 (Part 1)
1734	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IS 12640 (Part 2)
1735	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IS 12640 (Part 2)
1736	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IS 12640 (Part 2)
1737	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of circuit breaker after short circuit test	IS 12640 (Part 2)
1738	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60309 (Part -1)
1739	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60309 (Part 2)
1740	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60669 (Part 1)
1741	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60669 (Part 2-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	128 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1742	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60898 (Part 1)
1743	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 61008 (Part 1)
1744	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 61009 (Part 2-1)
1745	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 61009 (Part 2-2)
1746	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC/EN 60898 (Part 2)
1747	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC/EN 61008 (Prat 1)
1748	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC/EN 61009 (Prat 1)
1749	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS 12640 (Part 1)
1750	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS 12640 (Part 2)
1751	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS 3854
1752	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator for household and similar applications	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS/IEC 60309 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	129 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1753	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator or household and similar applications	28-day testing	IEC/EN 60898 (Part 2)
1754	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator or household and similar applications	Behaviour in case of surge currents	IEC/EN 61009 (Part 1)
1755	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator or household and similar applications	Behaviour in case of surge currents	IS 12640 (Part 1)
1756	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator or household and similar applications	Behaviour of circuit breakers in case of failure of the line voltage	IEC 61008 (Part 1)
1757	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolator or household and similar applications	Reliability of screws, current carrying parts and connectors	IEC 61008 (Part 2-1)
1758	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolatorfor household and similar applications	Dielectric Strength of main circuit	IEC 60898 (Part 2)
1759	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolatorfor household and similar applications	Mechanism/ Trip free mechanism	IEC/EN 61009 (Prat 1)
1760	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switch and isolatorfor household and similar applications	Residual operating characteristic	IEC 61009 (Part 1)
1761	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IE 60068 (Part 2-14)
1762	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IE 60068 (Part 2-14)
1763	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IEC 60068 (Part 2-30)
1764	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IEC 60068 (Part 2-30)
1765	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IEC 60947 (Part 1)
1766	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 130 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1767	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IEC 60947 (Part 5-2)
1768	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IEC 60947 (Part 5-2)
1769	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IEC 60947 (Part 5-3)
1770	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IEC 60947 (Part 5-3)
1771	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IEC 60947 (Part 6-1)
1772	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IEC 60947 (Part 6-1)
1773	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IS/IEC 60947 (Part 1)
1774	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IS/IEC 60947 (Part 1)
1775	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dry heat	IS/IEC 60947 (Part 5-2)
1776	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Clearances and creepage Distances	IEC 60947 (Part 1)
1777	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Clearances and creepage Distances	IEC 60947 (Part 3)
1778	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Clearances and creepage Distances	IEC 60947 (Part 5-2)
1779	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Clearances and creepage Distances	IEC 60947 (Part 6-1)
1780	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Clearances and creepage Distances	IS/IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 131 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1781	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Clearances and creepage Distances	IS/IEC 60947 (Part 3)
1782	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Clearances and creepage Distances	IS/IEC 60947 (Part 5-2)
1783	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 1)
1784	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 1)
1785	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 1)
1786	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 3)
1787	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 3)
1788	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 3)
1789	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 5-2)
1790	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 5-2)
1791	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 5-2)
1792	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 6-1)
1793	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 6-1)
1794	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IEC 60947 (Part 6-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	132 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1795	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IS/IEC 60947 (Part 1)
1796	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IS/IEC 60947 (Part 1)
1797	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IS/IEC 60947 (Part 1)
1798	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IS/IEC 60947 (Part 3)
1799	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IS/IEC 60947 (Part 3)
1800	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IS/IEC 60947 (Part 3)
1801	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IS/IEC 60947 (Part 5-2)
1802	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IS/IEC 60947 (Part 5-2)
1803	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Conditional short Circuit current	IS/IEC 60947 (Part 5-2)
1804	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Degree of protection; Protection against electric shock	IEC 60529
1805	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Degree of protection; Protection against electric shock	IEC 60947 (Part 1)
1806	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Degree of protection; Protection against electric shock	IS/IEC 60947 (Part 1)
1807	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IEC 60947 (Part 1)
1808	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	133 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1809	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IEC 60947 (Part 3)
1810	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IEC 60947 (Part 3)
1811	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IEC 60947 (Part 5-2)
1812	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IEC 60947 (Part 5-2)
1813	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IEC 60947 (Part 6-1)
1814	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IEC 60947 (Part 6-1)
1815	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IS/IEC 60947 (Part 1)
1816	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IS/IEC 60947 (Part 1)
1817	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IS/IEC 60947 (Part 3)
1818	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IS/IEC 60947 (Part 3)
1819	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IS/IEC 60947 (Part 5-2)
1820	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric properties	IS/IEC 60947 (Part 5-2)
1821	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 1)
1822	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	134 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1823	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 1)
1824	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 3)
1825	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 3)
1826	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 3)
1827	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 5-2)
1828	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 5-2)
1829	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 5-2)
1830	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 6-1)
1831	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 6-1)
1832	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IEC 60947 (Part 6-1)
1833	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IS/IEC 60947 (Part 1)
1834	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IS/IEC 60947 (Part 1)
1835	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IS/IEC 60947 (Part 1)
1836	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IS/IEC 60947 (Part 3)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	135 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1837	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IS/IEC 60947 (Part 3)
1838	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IS/IEC 60947 (Part 3)
1839	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IS/IEC 60947 (Part 5-2)
1840	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IS/IEC 60947 (Part 5-2)
1841	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Impulse test)	IS/IEC 60947 (Part 5-2)
1842	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IEC 60669
1843	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IEC 60669
1844	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 1)
1845	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 1)
1846	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 3)
1847	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 5-2)
1848	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 5-2)
1849	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 6-1)
1850	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IEC 60947 (Part 6-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	136 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1851	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IS 3854
1852	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IS 3854
1853	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IS/IEC 60947 (Part 1)
1854	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IS/IEC 60947 (Part 1)
1855	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IS/IEC 60947 (Part 3)
1856	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IS/IEC 60947 (Part 3)
1857	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IS/IEC 60947 (Part 5-2)
1858	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Power frequency voltage withstand test)	IS/IEC 60947 (Part 5-2)
1859	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Dielectric test (Powre frequency voltage withstand test)	IEC 60669
1860	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Environment test Dry heat	IS/IEC 60947 (Part 5-2)
1861	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IEC 60947 (Part 1)
1862	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IEC 60947 (Part 1)
1863	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IEC 60947 (Part 1)
1864	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IEC 60947 (Part 3)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 137 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1865	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IEC 60947 (Part 3)
1866	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IEC 60947 (Part 3)
1867	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IS/IEC 60947 (Part 1)
1868	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IS/IEC 60947 (Part 1)
1869	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IS/IEC 60947 (Part 1)
1870	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IS/IEC 60947 (Part 3)
1871	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IS/IEC 60947 (Part 3)
1872	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit making	IS/IEC 60947 (Part 3)
1873	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IEC 60947 (Part 1)
1874	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IEC 60947 (Part 1)
1875	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IEC 60947 (Part 1)
1876	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IEC 60947 (Part 3)
1877	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IEC 60947 (Part 3)
1878	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IEC 60947 (Part 3)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	138 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1879	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IS/IEC 60947 (Part 1)
1880	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IS/IEC 60947 (Part 1)
1881	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IS/IEC 60947 (Part 1)
1882	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IS/IEC 60947 (Part 3)
1883	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IS/IEC 60947 (Part 3)
1884	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Fuse protected short circuit withstand	IS/IEC 60947 (Part 3)
1885	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Glow wire	IEC 60669 (Part 1)
1886	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Glow wire	IEC 60695 (Part 2-10)
1887	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Glow wire	IEC 60695 (Part 2-11)
1888	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Glow wire	IEC 60947 (Part 1)
1889	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Glow wire	IS/IEC 60947 (Part 1)
1890	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IEC 60947 (Part 1)
1891	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IEC 60947 (Part 1)
1892	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IEC 60947 (Part 3)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 139 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1893	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IEC 60947 (Part 5-2)
1894	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IEC 60947 (Part 5-2)
1895	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IEC 60947 (Part 6-1)
1896	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IEC 60947 (Part 6-1)
1897	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IS/IEC 60947 (Part 1)
1898	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IS/IEC 60947 (Part 1)
1899	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IS/IEC 60947 (Part 3)
1900	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IS/IEC 60947 (Part 3)
1901	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IS/IEC 60947 (Part 5-2)
1902	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Leakage current	IS/IEC 60947 (Part 5-2)
1903	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 1)
1904	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 1)
1905	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 1)
1906	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 3)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 140 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1907	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 3)
1908	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 3)
1909	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 5-2)
1910	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 5-2)
1911	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 5-2)
1912	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 5-3)
1913	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 5-3)
1914	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 5-3)
1915	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 6-1)
1916	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 6-1)
1917	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IEC 60947 (Part 6-1)
1918	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IS/IEC 60947 (Part 1)
1919	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IS/IEC 60947 (Part 1)
1920	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IS/IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 141 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1921	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IS/IEC 60947 (Part 3)
1922	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IS/IEC 60947 (Part 3)
1923	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IS/IEC 60947 (Part 3)
1924	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IS/IEC 60947 (Part 5-2)
1925	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IS/IEC 60947 (Part 5-2)
1926	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Making & breaking capacity	IS/IEC 60947 (Part 5-2)
1927	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Mechanical operational performance capability	IEC 60947 (Part 1)
1928	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Mechanical operational performance capability	IEC 60947 (Part 3)
1929	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Mechanical operational performance capability	IEC 60947 (Part 6-1)
1930	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Mechanical operational performance capability	IS/IEC 60947 (Part 1)
1931	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Mechanical operational performance capability	IS/IEC 60947 (Part 3)
1932	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IE 60068 (Part 2-14)
1933	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IE 60068 (Part 2-14)
1934	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IEC 60068 (Part 2-30)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 142 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1935	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IEC 60068 (Part 2-30)
1936	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IEC 60947 (Part 1)
1937	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IEC 60947 (Part 1)
1938	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IEC 60947 (Part 5-2)
1939	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IEC 60947 (Part 5-2)
1940	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IEC 60947 (Part 6-1)
1941	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IEC 60947 (Part 6-1)
1942	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IS/IEC 60947 (Part 1)
1943	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IS/IEC 60947 (Part 1)
1944	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IS/IEC 60947 (Part 5-2)
1945	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Moisture and humidity test	IS/IEC 60947 (Part 5-2)
1946	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operation and operating limits	IEC 60947 (Part 1)
1947	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operation and operating limits	IEC 60947 (Part 1)
1948	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operation and operating limits	IEC 60947 (Part 5-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 143 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1949	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operation and operating limits	IEC 60947 (Part 5-2)
1950	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operation and operating limits	IEC 60947 (Part 6-1)
1951	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operation and operating limits	IEC 60947 (Part 6-1)
1952	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operation and operating limits	IS/IEC 60947 (Part 1)
1953	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operation and operating limits	IS/IEC 60947 (Part 1)
1954	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operation and operating limits	IS/IEC 60947 (Part 5-2)
1955	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operation and operating limits	IS/IEC 60947 (Part 5-2)
1956	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operational performance	IEC 60947 (Part 3)
1957	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operational performance	IEC 60947 (Part 1)
1958	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operational performance	IEC 60947 (Part 5-2)
1959	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operational performance	IEC 60947 (Part 6-1)
1960	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Operational performance	IS/IEC 60947 (Part 3)
1961	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Overload performance	IEC 60947 (Part 1)
1962	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Overload performance	IEC 60947 (Part 3)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 144 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1963	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Overload performance	IS/IEC 60947 (Part 1)
1964	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Overload performance	IS/IEC 60947 (Part 3)
1965	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IEC 60947 (Part 5-2)
1966	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IEC 60947 (Part 5-2)
1967	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IEC 60947 (Part 5-2)
1968	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IEC 60947 (Part 6-1)
1969	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IEC 60947 (Part 6-1)
1970	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IEC 60947 (Part 6-1)
1971	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IS/IEC 60947 (Part 1)
1972	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IS/IEC 60947 (Part 1)
1973	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IS/IEC 60947 (Part 1)
1974	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IS/IEC 60947 (Part 5-2)
1975	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IS/IEC 60947 (Part 5-2)
1976	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Performance under short circuit conditions	IS/IEC 60947 (Part 5-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 145 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1977	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 1)
1978	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 1)
1979	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 1)
1980	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 3)
1981	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 3)
1982	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 3)
1983	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 5-2)
1984	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 5-2)
1985	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 5-2)
1986	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 5-3)
1987	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 5-3)
1988	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 5-3)
1989	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 6-1)
1990	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 6-1)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	146 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
1991	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IEC 60947 (Part 6-1)
1992	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IS/IEC 60947 (Part 1)
1993	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IS/IEC 60947 (Part 1)
1994	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IS/IEC 60947 (Part 1)
1995	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IS/IEC 60947 (Part 3)
1996	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IS/IEC 60947 (Part 3)
1997	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IS/IEC 60947 (Part 3)
1998	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IS/IEC 60947 (Part 5-2)
1999	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IS/IEC 60947 (Part 5-2)
2000	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short circuit making capacity	IS/IEC 60947 (Part 5-2)
2001	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IEC 60947 (Part 1)
2002	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IEC 60947 (Part 1)
2003	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IEC 60947 (Part 1)
2004	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IEC 60947 (Part 3)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 147 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
2005	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IEC 60947 (Part 3)
2006	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IEC 60947 (Part 3)
2007	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IEC 60947 (Part 6-1)
2008	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IEC 60947 (Part 6-1)
2009	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IEC 60947 (Part 6-1)
2010	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IS/IEC 60947 (Part 1)
2011	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IS/IEC 60947 (Part 1)
2012	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IS/IEC 60947 (Part 1)
2013	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IS/IEC 60947 (Part 3)
2014	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IS/IEC 60947 (Part 3)
2015	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Short time withstand current	IS/IEC 60947 (Part 3)
2016	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Strength of actuator mechanism	IEC 60947 (Part 1)
2017	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Strength of actuator mechanism	IEC 60947 (Part 3)
2018	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Strength of actuator mechanism	IS/IEC 60947 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 148 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
2019	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Strength of actuator mechanism	IS/IEC 60947 (Part 3)
2020	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IEC 60947 (Part 1)
2021	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IEC 60947 (Part 1)
2022	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IEC 60947 (Part 3)
2023	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IEC 60947 (Part 3)
2024	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IEC 60947 (Part 5-2)
2025	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IEC 60947 (Part 5-2)
2026	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IEC 60947 (Part 6-1)
2027	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IEC 60947 (Part 6-1)
2028	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IS/IEC 60947 (Part 1)
2029	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IS/IEC 60947 (Part 1)
2030	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IS/IEC 60947 (Part 3)
2031	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IS/IEC 60947 (Part 3)
2032	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IS/IEC 60947 (Part 5-2)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 149 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
2033	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Temperature rise	IS/IEC 60947 (Part 5-2)
2034	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Verification of conventional operational performance	IEC 60947 (Part 1)
2035	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Verification of conventional operational performance	IEC 60947 (Part 6-1)
2036	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Verification of conventional operational performance	IS/IEC 60947 (Part 1)
2037	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60947 (Part 1)
2038	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60947 (Part 3)
2039	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60947 (Part 5-2)
2040	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60947 (Part 6-1)
2041	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS/IEC 60947 (Part 1)
2042	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS/IEC 60947 (Part 3)
2043	ELECTRICAL-SWITCHGEAR & PROTECTIVE EQUIPMENT	Switches & isolators	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS/IEC 60947 (Part 5-2)
2044	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Clearances and creepage Distances	IS 11037

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 150 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
2045	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Degree of protection; Protection against electric shock	IS 11037
2046	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dielectric properties	IS 11037
2047	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dielectric properties	IS 11037
2048	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dielectric test (Impulse test)	IS 11037
2049	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dielectric test (Impulse test)	IS 11037
2050	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dielectric test (Impulse test)	IS 11037
2051	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dielectric test (Power frequency voltage withstand test)	IS 11037
2052	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dielectric test (Power frequency voltage withstand test)	IS 11037
2053	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dry heat	IEC 60068 (Part 2-14)
2054	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dry heat	IEC 60068 (Part 2-14)
2055	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dry heat	IEC 60068 (Part 2-30)
2056	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dry heat	IEC 60068 (Part 2-30)
2057	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dry heat	IS 11037
2058	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Dry heat	IS 11037
2059	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Mechanical operational performance capability	IS 11037
2060	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Moisture and humidity test	IEC 60068 (Part 2-14)
2061	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Moisture and humidity test	IEC 60068 (Part 2-14)
2062	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Moisture and humidity test	IEC 60068 (Part 2-30)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 151 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
2063	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Moisture and humidity test	IEC 60068 (Part 2-30)
2064	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Moisture and humidity test	IS 11037
2065	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator	Moisture and humidity test	IS 11037
2066	ELECTRICAL- WIRING ACCESSORIES	Electronic type fan regulator, 120 watts	Temperature rise	IS 11037
2067	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dry heat	IEC 60068 (Part 2-14)
2068	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dry heat	IEC 60068 (Part 2-14)
2069	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dry heat	IEC 60068 (Part 2-30)
2070	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dry heat	IEC 60068 (Part 2-30)
2071	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Clearances and creepage Distances	IEC 60884 (Part 1)
2072	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Clearances and creepage Distances	IS 1293
2073	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Degree of protection; Protection against electric shock	IEC 60529
2074	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric properties	IEC 60884 (Part 1)
2075	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric properties	IEC 60884 (Part 1)
2076	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric properties	IS 1293
2077	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric properties	IS 1293
2078	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric test (Power frequency voltage withstand test)	IEC 60695 (Part 2-10)
2079	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric test (Power frequency voltage withstand test)	IEC 60695 (Part 2-10)

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	152 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
2080	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric test (Power frequency voltage withstand test)	IEC 60695 (Part 2-11)
2081	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric test (Power frequency voltage withstand test)	IEC 60695 (Part 2-11)
2082	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric test (Power frequency voltage withstand test)	IEC 60884 (Part 1)
2083	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric test (Power frequency voltage withstand test)	IEC 60884 (Part 1)
2084	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric test (Power frequency voltage withstand test)	IS 1293
2085	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dielectric test (Power frequency voltage withstand test)	IS 1293
2086	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dry heat	IEC 60884 (Part 1)
2087	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dry heat	IEC 60884 (Part 1)
2088	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dry heat	IS 1293
2089	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Dry heat	IS 1293
2090	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Glow wire	IEC 60884 (Part 1)
2091	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Glow wire	IS 1293
2092	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Making & breaking capacity	IEC 60884 (Part 1)
2093	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Making & breaking capacity	IEC 60884 (Part 1)
2094	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Making & breaking capacity	IS 1293
2095	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Making & breaking capacity	IS 1293
2096	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Mechanical operational performance capability	IEC 60884 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 153 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
2097	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Mechanical Switches normal operation capability	IS 1293
2098	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Moisture and humidity test	IEC 60068
2099	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Moisture and humidity test	IEC 60068 (Part 2-14)
2100	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Moisture and humidity test	IEC 60068 (Part 2-30)
2101	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Moisture and humidity test	IEC 60068 (Part 2-30)
2102	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Moisture and humidity test	IEC 60669 (Part 1)
2103	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Moisture and humidity test	IEC 60669 (Part 1)
2104	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Moisture and humidity test	IS 1293
2105	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Moisture and humidity test	IS 1293
2106	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Operational performance	IEC 60884 (Part 1)
2107	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Operational performance	IS 1293
2108	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Short circuit making capacity	IEC 60884 (Part 1)
2109	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Short circuit making capacity	IEC 60884 (Part 1)
2110	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Short circuit making capacity	IS 1293
2111	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Short circuit making capacity	IS 1293
2112	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Temperature rise	IEC 60884 (Part 1)
2113	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Temperature rise	IS 1293
2114	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60884 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 154 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
2115	ELECTRICAL- WIRING ACCESSORIES	Plugs & sockets	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS 1293
2116	ELECTRICAL- WIRING ACCESSORIES	Switches	Dry heat	IS 3854
2117	ELECTRICAL- WIRING ACCESSORIES	Switches	Dry heat	IE 60068 (Part 2-14)
2118	ELECTRICAL- WIRING ACCESSORIES	Switches	Dry heat	IE 60068 (Part 2-14)
2119	ELECTRICAL- WIRING ACCESSORIES	Switches	Dry heat	IEC 60068 (Part 2-30)
2120	ELECTRICAL- WIRING ACCESSORIES	Switches	Dry heat	IEC 60068 (Part 2-30)
2121	ELECTRICAL- WIRING ACCESSORIES	Switches	Dry heat	IEC 60669
2122	ELECTRICAL- WIRING ACCESSORIES	Switches	Dry heat	IS 3854
2123	ELECTRICAL- WIRING ACCESSORIES	Switches	Clearances and creepage Distances	IEC 60669 (Part 1)
2124	ELECTRICAL- WIRING ACCESSORIES	Switches	Clearances and creepage Distances	IS 3854
2125	ELECTRICAL- WIRING ACCESSORIES	Switches	Conditional short Circuit current	IEC 60669 (Part 1)
2126	ELECTRICAL- WIRING ACCESSORIES	Switches	Conditional short Circuit current	IEC 60669 (Part 1)
2127	ELECTRICAL- WIRING ACCESSORIES	Switches	Conditional short Circuit current	IEC 60669 (Part 1)
2128	ELECTRICAL- WIRING ACCESSORIES	Switches	Conditional short Circuit current	IS 3854
2129	ELECTRICAL- WIRING ACCESSORIES	Switches	Conditional short Circuit current	IS 3854
2130	ELECTRICAL- WIRING ACCESSORIES	Switches	Conditional short Circuit current	IS 3854
2131	ELECTRICAL- WIRING ACCESSORIES	Switches	Degree of protection; Protection against electric shock	IEC 60529
2132	ELECTRICAL- WIRING ACCESSORIES	Switches	Dielectric properties	IEC 60669 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 155 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
2133	ELECTRICAL- WIRING ACCESSORIES	Switches	Dielectric properties	IEC 60669 (Part 1)
2134	ELECTRICAL- WIRING ACCESSORIES	Switches	Dielectric properties	IS 3854
2135	ELECTRICAL- WIRING ACCESSORIES	Switches	Dielectric properties	IS 3854
2136	ELECTRICAL- WIRING ACCESSORIES	Switches	Environment test Dry heat	IEC 60669
2137	ELECTRICAL- WIRING ACCESSORIES	Switches	Glow wire	IEC 60669 (Part 1)
2138	ELECTRICAL- WIRING ACCESSORIES	Switches	Glow wire	IEC 60695 (Part 2-10)
2139	ELECTRICAL- WIRING ACCESSORIES	Switches	Glow wire	IEC 60695 (Part 2-11)
2140	ELECTRICAL- WIRING ACCESSORIES	Switches	Glow wire	IS 3854
2141	ELECTRICAL- WIRING ACCESSORIES	Switches	Making & breaking capacity	IEC 60669 (Part 1)
2142	ELECTRICAL- WIRING ACCESSORIES	Switches	Making & breaking capacity	IEC 60669 (Part 1)
2143	ELECTRICAL- WIRING ACCESSORIES	Switches	Making & breaking capacity	IS 3854
2144	ELECTRICAL- WIRING ACCESSORIES	Switches	Making & breaking capacity	IS 3854
2145	ELECTRICAL- WIRING ACCESSORIES	Switches	Mechanical operational performance capability	IEC 60669 (Part 1)
2146	ELECTRICAL- WIRING ACCESSORIES	Switches	Mechanical Switches normal operation capability	IS 3854
2147	ELECTRICAL- WIRING ACCESSORIES	Switches	Moisture and humidity test	IE 60068 (Part 2-14)
2148	ELECTRICAL- WIRING ACCESSORIES	Switches	Moisture and humidity test	IEC 60068 (Part 2-14)
2149	ELECTRICAL- WIRING ACCESSORIES	Switches	Moisture and humidity test	IEC 60068 (Part 2-30)
2150	ELECTRICAL- WIRING ACCESSORIES	Switches	Moisture and humidity test	IEC 60068 (Part 2-30)
2151	ELECTRICAL- WIRING ACCESSORIES	Switches	Moisture and humidity test	IEC 60669 (Part 1)

SCOPE OF ACCREDITATION

Laboratory Name : SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA

Accreditation Standard ISO/IEC 17025:2017

Certificate Number TC-6328 **Page No** 156 of 157

Validity 31/07/2021 to 30/07/2023 **Last Amended on** 06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
2152	ELECTRICAL- WIRING ACCESSORIES	Switches	Moisture and humidity test	IEC 60669 (Part 1)
2153	ELECTRICAL- WIRING ACCESSORIES	Switches	Moisture and humidity test	IS 3854
2154	ELECTRICAL- WIRING ACCESSORIES	Switches	Moisture and humidity test	IS 3854
2155	ELECTRICAL- WIRING ACCESSORIES	Switches	Operation and operating limits	IEC 60669 (Part 1)
2156	ELECTRICAL- WIRING ACCESSORIES	Switches	Operation and operating limits	IEC 60669 (Part 1)
2157	ELECTRICAL- WIRING ACCESSORIES	Switches	Operation and operating limits	IS 3854
2158	ELECTRICAL- WIRING ACCESSORIES	Switches	Operation and operating limits	IS 3854
2159	ELECTRICAL- WIRING ACCESSORIES	Switches	Operational performance	IEC 60669 (Part 1)
2160	ELECTRICAL- WIRING ACCESSORIES	Switches	Short circuit making capacity	IEC 60669 (Part 1)
2161	ELECTRICAL- WIRING ACCESSORIES	Switches	Short circuit making capacity	IEC 60669 (Part 1)
2162	ELECTRICAL- WIRING ACCESSORIES	Switches	Short circuit making capacity	IEC 60669 (Part 1)
2163	ELECTRICAL- WIRING ACCESSORIES	Switches	Short circuit making capacity	IS 3854
2164	ELECTRICAL- WIRING ACCESSORIES	Switches	Short circuit making capacity	IS 3854
2165	ELECTRICAL- WIRING ACCESSORIES	Switches	Short circuit making capacity	IS 3854
2166	ELECTRICAL- WIRING ACCESSORIES	Switches	Temperature rise	IEC 60669 (Part 1)
2167	ELECTRICAL- WIRING ACCESSORIES	Switches	Temperature rise	IS 3854
2168	ELECTRICAL- WIRING ACCESSORIES	Switches	Verification of Marking, dimensions, visual examination, General, constructional requirements	IEC 60669 (Part 1)

National Accreditation Board for Testing and Calibration Laboratories

SCOPE OF ACCREDITATION

Laboratory Name :	SWITCHGEAR TESTING LABORATORIES, SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED, GATE NO 1, POWAI CAMPUS, SAKI-VIHAR ROAD, POWAI, MUMBAI, MAHARASHTRA, INDIA		
Accreditation Standard	ISO/IEC 17025:2017		
Certificate Number	TC-6328	**Page No**	157 of 157
Validity	31/07/2021 to 30/07/2023	**Last Amended on**	06/09/2021

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
2169	ELECTRICAL- WIRING ACCESSORIES	Switches	Verification of Marking, dimensions, visual examination, General, constructional requirements	IS 3854
2170	ELECTRICAL- WIRING ACCESSORIES	Switches, 10A, one way	Switches normal operation	IS 3854